


RECEIVED
30 JUN 2011
PLANNING


11/1581/FUL



SIDE ELEVATION



FIRST FLOOR ROOF PLAN



GROUND FLOOR PLAN

- F. EXHAUST DUCT IN PLASTI AREA REPOSITIONED 25/02/11
- E. CONDENSING UNITS RELOCATED. REVISED EXHAUST DUCT. HIGH VELOCITY DISCHARGE RELOCATED TO POSITION OF REDUNDANT WATER TANK 24/02/11.
- B. HIGH VELOCITY DISCHARGE DUCT ADDED. ULTRA VIOLET LAMPS OMITTED JUN 2011.
- A. CONDENSING UNITS RESET ON TO SIDE WALL. ADDITIONAL FAN ACOUSTIC MUFFLERS ADDED. FENCING ADDED TO SHIELD LOW LEVEL DUCTWORK 16/12/10.

REVISIONS	DATE
TITLE	
PROPOSED KITCHEN VENTILATION SYSTEMS.	
SITE	
JENNY LIND - 80 HIGH STREET	
HAMPDEN HILL - TW12 1NY	
CLIENT	
ANDREW J H SAITEL ESQ.	

RJR Services Ltd
Vickers House
Priestley Road
Basingstoke
Hants RG24 9NP

DATE: 25/11/10. SCALE: 1/5000. DRAWING NO: 30189/1F