

Site c/o Garden Road /Orchard Road Richmond Upon Thames TW9

Flat	Room	Elevation	Measurement using PPG 24 Methodology			Measurement using BS 4142:19997 Methodology		Result	Proposed Mitigation	Ventilation
					Result					
14 C	Bedroom (1)	Market Rd	64	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Market Rd	64	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Living Room	Market Rd	64	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Market Rd	64	61	Pass	n/a	n/a	n/a	None Required	Trickle
13 C	Living Room	Garden Rd/Market Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
12 C	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
11 C	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (3)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
10 C	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
9 C	Living Room	Courtyard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
	Bedroom (1)	Courtyard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
	Bedroom (2)	Courtyard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
8 C	Living Room	Courtyard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
	Bedroom (1)	Courtyard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
	Bedroom (2)	Courtyard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
7 C	Living Room	Court Yard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle

Site c/o Garden Road /Orchard Road Richmond Upon Thames TW9

Flat	Room	Elevation	Measurement using PPG 24 Methodology		Result	Measurement using BS 4142:19997 Methodology		Result	Proposed Mitigation	Ventilation
	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
<b>SECOND FLOOR Block A</b>										
	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
6A	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
	Bedroom (2)	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
7A	Living Room	DAIRY	64	61	Pass	n/a	Rating Level +9dB	Pass	Secondary glazing / Laminate sealed double glazed units	
	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
	Bedroom (2)	DAIRY	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
						n/a				
	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
8A	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
9A	Bedroom (1)	H V	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
	Bedroom (2)	HV	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
	Living Room	H V	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
10 A	Bedroom (1)	H V	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
	Bedroom (2)	HV	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle

**Second Floor**

**Block B**

Flat	Room	Elevation								
11 B	Living Room	Court Yard	64	61	Pass	Pass	Rating Level -1 dB	Pass	None Required	Trickle
	Bedroom (1)	Orchard Rd	64	61	Pass	Pass	Rating Level +6	Pass	None Required	Trickle

Site c/o Garden Road /Orchard Road Richmond Upon Thames TW9

Flat	Room	Elevation	Measurement using PPG 24 Methodology		Result	Measurement using BS 4142:1997 Methodology		Result	Proposed Mitigation	Ventilation
							dB			
12 B	Bedroom (2)	Orchard Rd	64	61	Pass	Pass	Rating Level +6 dB	Pass	None Required	Trickle
	Living Room	Orchard Rd	64	61	Pass	Pass	Rating Level +6 dB	Pass	None Required	Trickle
	Bedroom (1)	Orchard Rd	64	61	Pass	Pass	Rating Level +6 dB	Pass	None Required	Trickle
13 B	Living Room	Orchard Rd	64	61	Pass	Pass	Rating Level +6 dB	Pass	None Required	Trickle
	Bedroom (1)	Orchard Rd	64	61	Pass	Pass	Rating Level +6 dB	Pass	None Required	Trickle
	Bedroom (2)	Orchard Rd	64	61	Pass	Pass	Rating Level +6 dB			Trickle
14 B	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
15 B	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
16 B	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
17 B	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
18 B	Living Room	Court Yard	64	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Court Yard	64	61	Pass	n/a	n/a	n/a	None Required	Trickle

2nd Floor Block C

Flat Room Elevation

Site c/o Garden Road /Orchard Road Richmond Upon Thames TW9

Flat	Room	Elevation	Measurement using PPG 24 Methodology			Measurement using BS 4142:1997 Methodology			Proposed Mitigation	Ventilation
			64	61	Result	n/a	Rating Level +4 dB	Result		
16 C	Living Room	Court Yard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
17 C	Living Room	Court Yard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
	Bedroom (2)	Court Yard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
18 C	Living Room	Court Yard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
	Bedroom (2)	Court Yard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
19 C	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
20 C	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (3)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
21 C	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
22 C	Living Room	Garden Rd/Market Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
23 C	Living Room	Market Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Market Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle

Site c/o Garden Road /Orchard Road Richmond Upon Thames TW9

Flat	Room	Elevation	Measurement using PPG 24 Methodology			Measurement using BS 4142:1997 Methodology		Result	Proposed Mitigation	Ventilation
					Result					
24 C	Bedroom (2)	Market Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Living Room	Market Rd	64	61	Pass	n/a	n/a	n/a	None Required	
	Bedroom (1)	Market Rd	64	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Market Rd	64	61	Pass	n/a	n/a	n/a	None Required	Trickle
<b>Third Floor</b>										
11 A	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
12 A	Living Room	Court Yard	64	61	Pass	n/a	n/a	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
13 A	Living Room	Court Yard	64	61	Pass	n/a	n/a	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
14 A	Living Room	Court Yard	64	61	Pass	n/a	n/a	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
15 A	Living Room	Court Yard	64	61	Pass	n/a	n/a	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
	Bedroom (2)	Court Yard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
16 A	Living Room	Market Rd	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
	Bedroom (1)	Market Rd	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
<b>Block B</b>										
20 B	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle

Site c/o Garden Road /Orchard Road Richmond Upon Thames TW9

Flat	Room	Elevation	Measurement using PPG 24 Methodology		Result	Measurement using BS 4142:1997 Methodology		Result	Proposed Mitigation	Ventilation
21 B	Bedroom (1)	Orchard Rd	64	61	Pass	n/a	Rating Level +6 dB	Pass	None Required	Trickle
	Bedroom (2)	Orchard Rd	64	61	Pass	n/a	Rating Level +6 dB	Pass	None Required	Trickle
	Living Room	Court Yard	64	61	Pass	n/a	Rating Level +6 dB	Pass	None Required	Trickle
	Bedroom (1)	Orchard Rd	64	61	Pass	n/a	Rating Level +6 dB	Pass	None Required	Trickle
22 B	Living Room	Orchard Rd	64	61	Pass	n/a	Rating Level +6 dB	Pass	None Required	Trickle
	Bedroom (1)	Orchard Rd	64	61	Pass	n/a	Rating Level +6 dB	Pass	None Required	Trickle
	Bedroom (2)	Orchard Rd	64	61	Pass	n/a	Rating Level +6 dB	Pass	None Required	Trickle
23 B	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
24 B	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
25 B	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
26 B	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
27 B	Living Room	Court Yard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level +4 dB	Pass	None Required	Trickle
<b>Block C</b>										
25 C	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle

Site c/o Garden Road /Orchard Road Richmond Upon Thames TW9

Flat	Room	Elevation	Measurement using PPG 24 Methodology		Result	Measurement using BS 4142:19997 Methodology		Result	Proposed Mitigation	Ventilation
26 C	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
	Bedroom (2)	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
27 C	Living Room	Garden Rd	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
	Bedroom (1)	Garden Rd	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
	Bedroom (2)	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
28 C	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
29 C	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (3)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
30 C	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
31 C	Living Room	Market Rd/Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Market Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Market Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
32 C	Living Room	Market Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Market Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
33 C	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
	Bedroom (1)	Market Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle

Site c/o Garden Road /Orchard Road Richmond Upon Thames TW9

Flat	Room	Elevation	Measurement using PPG 24 Methodology			Measurement using BS 4142:1997 Methodology		Result	Proposed Mitigation	Ventilation
					Result					
	Bedroom (2)	Market Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
<b>Fourth Floor</b>										
<b>Block A</b>										
Flat	Room	Elevation			Result			Result	Proposed Mitigation	Ventilation
	Living Room	Orchard Rd	64	61	Pass	n/a	Rating Level +6 dB	Pass	None Required	Trickle
17 A	Bedroom (1)	Orchard Rd	64	61	Pass	n/a	Rating Level +6 dB	Pass	None Required	Trickle
	Bedroom (2)	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
18 A	Living Room	Orchard Rd	64	61	Pass	n/a	Rating Level +6 dB	Pass	None Required	Trickle
	Bedroom (1)	Orchard Rd	64	61	Pass	n/a	Rating Level +6 dB	Pass	None Required	Trickle
19 A	Living Room	Orchard Rd	64	61	Pass	n/a	Rating Level +6 dB	Pass	None Required	Trickle
	Bedroom (1)	Orchard Rd	64	61	Pass	n/a	Rating Level +6 dB	Pass	None Required	Trickle
20 A	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
21 A	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
22 A	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
23 A	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	Pass	None Required	Trickle
	Bedroom (1)	Dairy	64	61	Pass	n/a	Rating Level +6 dB	Pass	None Required	Trickle
24 A	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1 dB	n/a	None Required	Trickle



Site c/o Garden Road /Orchard Road Richmond Upon Thames TW9

Flat	Room	Elevation	Measurement using PPG 24 Methodology			Measurement using BS 4142:19997 Methodology		Result	Proposed Mitigation	Ventilation
			64	61	Pass	n/a	n/a			
25 A	Bedroom (1)	Market Rd	64	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Market Rd	64	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Living Room	Market Rd	64	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Market Rd	64	61	Pass	n/a	n/a	n/a	None Required	Trickle
<b>Block B</b>										
Flat	Room	Elevation								
29 B	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1	n/a	None Required	Trickle
	Bedroom (1)	Orchard Rd	64	61	Pass	n/a	Rating Level +6	n/a	None Required	Trickle
	Bedroom (2)	Orchard Rd	64	61	Pass	n/a	Rating Level +6	n/a	None Required	Trickle
30 B	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1	n/a	None Required	Trickle
	Bedroom (1)	Orchard Rd	64	61	Pass	n/a	Rating Level +6	n/a	None Required	Trickle
	Bedroom (2)	Orchard Rd	64	61	Pass	n/a	Rating Level +6	n/a	None Required	Trickle
31 B	Living Room	Orchard Rd	64	61	Pass	n/a	Rating Level +6	Pass	None Required	Trickle
	Bedroom (1)	Orchard Rd	64	61	Pass	n/a	Rating Level +6	Pass	None Required	Trickle
	Bedroom (2)	Orchard Rd	64	61	Pass	n/a	Rating Level +6	Pass	None Required	Trickle
	Bedroom (3)	Orchard Rd	64	61	Pass	n/a	Rating Level +6	Pass	None Required	Trickle
32 B	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
33 B	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
34 B	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle

Site c/o Garden Road /Orchard Road Richmond Upon Thames TW9

Flat	Room	Elevation	Measurement using PPG 24 Methodology		Result	Measurement using BS 4142:19997 Methodology		Result	Proposed Mitigation	Ventilation
35 B	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	Pass	Rating Level -1	Pass	None Required	Trickle
36 B	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	Pass	Rating Level -1	Pass	None Required	Trickle
<b>Block C</b>										
Flat	Room	Elevation								
34 C	Living Room	Court Yard	64	61	Pass	Pass	Rating Level -1	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	Pass	Rating Level -1	Pass	None Required	Trickle
35 C	Living Room	Court Yard	64	61	Pass	Pass	Rating Level -1	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	Pass	Rating Level -1	Pass	None Required	Trickle
36 C	Living Room	Court Yard	64	61	Pass	Pass	Rating Level -1	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	Pass	Rating Level -1	Pass	None Required	Trickle
37 C	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
38 C	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
39 C	Living Room	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	n/a	None Required	Trickle
40 C	Living Room	Garden Rd/Market Rd	64	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (1)	Market Rd	64	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Market Rd	64	61	Pass	n/a	n/a	n/a	None Required	Trickle
41 C	Living Room	Market Rd	64	61	Pass	Pass	n/a	n/a	None Required	Trickle
	Bedroom (1)	Market Rd	64	61	Pass	Pass	n/a	n/a	None Required	Trickle

Site c/o Garden Road /Orchard Road Richmond Upon Thames TW9

Flat	Room	Elevation	Measurement using PPG 24 Methodology		Result	Measurement using BS 4142:19997 Methodology		Result	Proposed Mitigation	Ventilation
42 C	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1	Pass	None Required	Trickle
	Bedroom (1)	Market Rd	64	61	Pass	n/a	n/a	n/a	None Required	Trickle
	Bedroom (2)	Market Rd	64	61	Pass	n/a	n/a	n/a	None Required	Trickle

Fifth Floor (Roof)

Block B

Flat	Room	Elevation	Measurement using PPG 24 Methodology		Result	Measurement using BS 4142:19997 Methodology		Result	Proposed Mitigation	Ventilation
37 B	Living Room	Orchard Rd	64	61	Pass	Pass	Rating Level +6	Pass	None Required	Trickle
	Bedroom (1)	Orchard Rd	64	61	Pass	Pass	Rating Level +6	Pass	None Required	Trickle
38 B	Living Room	Garden Rd	65	61	Pass	n/a	n/a	Pass	None Required	Trickle
	Bedroom (1)	Orchard Rd	64	61	Pass	Pass	Rating Level +6	Pass	None Required	Trickle
	Bedroom (2)	Orchard Rd	64	61	Pass	Pass	Rating Level +6	Pass	None Required	Trickle
39 B	Living Room	Garden Rd	65	61	Pass	n/a	n/a	Pass	None Required	Trickle
	Bedroom (1)	Garden Rd	65	61	Pass	n/a	n/a	Pass	None Required	Trickle
	Bedroom (2)	Garden Rd	65	61	Pass	n/a	n/a	Pass	None Required	Trickle
40 B	Living Room	Court Yard	64	61	Pass	n/a	Rating Level -1	Pass	None Required	Trickle
	Bedroom (1)	Court Yard	64	61	Pass	n/a	Rating Level -1	Pass	None Required	Trickle
	Bedroom (2)	Court Yard	64	61	Pass	n/a	Rating Level -1	Pass	None Required	Trickle