



NORMAL DEPTH TO THE TOP OF THE CABLE WHEN LAID					<div>WARNING</div> <p>There may have been subsequent alterations to the surface levels. Trial holes must be taken to determine positions and depth of cables. HS (G) 47 Booklet from the Health and Safety Executive – Avoiding Danger from Buried Cables – should be consulted before commencing excavation work. (available from HMSO)</p> <p>WHEN WORKING IN THE VICINITY OF OVERHEAD LINES THE HEALTH AND SAFETY GUIDANCE NOTE GS6 SHOULD BE CONSULTED. (AVAILABLE FROM HMSO)</p>	BASED UPON THE ORDNANCE SURVEY MAP WITH THE SANCTION OF THE CONTROLLER OF H.M. STATIONERY OFFICE. CROWN COPYRIGHT RESERVED.		 Scottish and Southern Energy	
services	l.v.	h.v.	e.h.v.	This copy has been made by or with the authority of SOUTHERN ELECTRIC p.l.c. pursuant to section 47 of the Copyright, Designs and Patents Act 1988 ('the Act'). Unless the Act provides a relevant exception to copyright, the copy must not be copied without the prior permission of the copyright owner. Template: SIAS NRSWA COL A3 plot		L.V. MAINS RECORD	Grid Ref: TQ15207387		
FOOTPATH	0.40m	0.45m	0.60m	0.75m		Scottish and Southern Energy plc. Registered in Scotland No 117119. Registered Office: Inverlismond House 200 Dunkeld Road, Perth, PH1 3AQ.	Mapping Services Unit 01256 337294	Scale: 1:1250	
ROAD CROSSING	0.60m	0.60m	0.75m	0.90m			UNCONTROLLED COPY	Date: 16/04/2015	
l.v./services	– up to 1000V.						Subject to Revision Master held at		
h.v.	– over 1000V. to 11,000V.								
e.h.v.	– 22,000V. to 132,000V.								



WARNING
GAS IN PLOT AREA

NORMAL DEPTH TO THE TOP OF THE PIPE WHEN LAID				<div>WARNING</div> <p>There may have been subsequent alterations to the surface levels. Trial holes must be taken to determine positions and depth of cables. HS (G) 47 Booklet from the Health and Safety Executive – Avoiding Danger from Buried Cables – should be consulted before commencing excavation work. (available from HMSO)</p> <p>WHEN WORKING IN THE VICINITY OF OVERHEAD LINES THE HEALTH AND SAFETY GUIDANCE NOTE GS6 SHOULD BE CONSULTED. (AVAILABLE FROM HMSO)</p>		BASED UPON THE ORDNANCE SURVEY MAP WITH THE SANCTION OF THE CONTROLLER OF H.M. STATIONERY OFFICE. CROWN COPYRIGHT RESERVED.		 Scottish and Southern Energy					
MAINS		SERVICES				This copy has been made by or with the authority of SOUTHERN ELECTRIC p.l.c. pursuant to section 47 of the Copyright, Designs and Patents Act 1988 ('the Act'). Unless the Act provides a relevant exception to copyright, the copy must not be copied without the prior permission of the copyright owner.							
FOOTPATH		0.60m		PRIVATE		0.375m		Template: SIAS NRSWA COL A3 plot GAS		GAS Record		Grid Ref: TQ15207387	
VERGE		0.75m		PUBLIC		0.45m		Scottish and Southern Energy plc. Registered in Scotland No 117119. Registered Office: Inverlmond House 200 Dunkeld Road, Perth, PH1 3AQ.		Mapping Services Unit 01256 337294		Scale: 1:1250	
ROAD		0.75m								UNCONTROLLED COPY		Date: 16/04/2015	
						Subject to Revision Master held at							