

Existing Network Details for Existing

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)
E1.000	5.965	0.050	119.3	0.036	5.00	0.0	0.600	o	225
E1.001	14.954	0.190	78.7	0.000	0.00	0.0	0.600	o	300
E1.002	35.573	0.130	273.6	0.126	0.00	0.0	0.600	o	300
E1.003	25.582	0.030	852.7	0.137	0.00	0.0	0.600	o	300
E1.004	27.484	0.024	1145.2	0.124	0.00	0.0	0.600	o	375
E1.005	44.814	0.046	974.2	0.157	0.00	0.0	0.600	o	375
E1.006	22.657	0.140	161.8	0.095	0.00	0.0	0.600	o	450
E1.007	13.394	0.070	191.3	0.031	0.00	0.0	0.600	o	450
E1.008	40.307	0.110	366.4	0.058	0.00	0.0	0.600	o	450
E1.009	58.164	0.090	646.3	0.082	0.00	0.0	0.600	o	450
E1.010	5.590	0.110	50.8	0.019	0.00	0.0	0.600	o	525
E2.000	29.453	0.030	981.8	0.081	5.00	0.0	0.600	o	225
E2.001	20.584	0.390	52.8	0.083	0.00	0.0	0.600	o	300
E3.000	19.866	0.200	99.3	0.110	5.00	0.0	0.600	o	225
E3.001	22.831	0.100	228.3	0.058	0.00	0.0	0.600	o	300
E3.002	22.210	0.130	170.8	0.062	0.00	0.0	0.600	o	300
E3.003	27.782	0.120	231.5	0.106	0.00	0.0	0.600	o	400
E3.004	7.201	0.130	55.4	0.080	0.00	0.0	0.600	o	400
E2.002	10.644	0.180	59.1	0.000	0.00	0.0	0.600	o	400

Network Results Table

PN	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Vel (m/s)	Cap (l/s)
E1.000	8.490	0.036	0.0	1.20	47.6
E1.001	8.440	0.036	0.0	1.77	125.4
E1.002	8.250	0.161	0.0	0.95	66.8
E1.003	8.120	0.298	0.0	0.53	37.5
E1.004	8.090	0.422	0.0	0.53	58.2
E1.005	8.066	0.579	0.0	0.57	63.2
E1.006	8.020	0.674	0.0	1.60	253.7
E1.007	7.880	0.705	0.0	1.47	233.2
E1.008	7.810	0.764	0.0	1.06	168.0
E1.009	7.700	0.845	0.0	0.79	126.0
E1.010	7.610	0.864	0.0	3.15	681.4
E2.000	8.150	0.081	0.0	0.41	16.3
E2.001	8.120	0.164	0.0	2.17	153.3
E3.000	8.360	0.110	0.0	1.31	52.2
E3.001	8.160	0.168	0.0	1.04	73.3
E3.002	8.060	0.230	0.0	1.20	84.8
E3.003	7.930	0.336	0.0	1.24	155.3
E3.004	7.810	0.415	0.0	2.54	319.2
E2.002	7.680	0.580	0.0	2.46	308.9

Existing Network Details for Existing

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)
E1.011	6.314	0.100	63.1	0.000	0.00	0.0	0.600	o	150
E1.012	4.433	0.044	100.8	0.000	0.00	0.0	0.600	o	150

Network Results Table


PN	US/IL (m)	I.Area (ha)	Σ Base Flow (l/s)	Vel (m/s)	Cap (l/s)
E1.011	5.530	1.444	0.0	1.27	22.4
E1.012	7.983	1.444	0.0	1.00	17.7

Simulation Criteria for Existing

Volumetric Runoff Coeff	0.750	Additional Flow - % of Total Flow	0.000
Areal Reduction Factor	1.000	MADD Factor * 10m ³ /ha Storage	2.000
Hot Start (mins)	0	Inlet Coefficient	0.800
Hot Start Level (mm)	0	Flow per Person per Day (l/per/day)	0.000
Manhole Headloss Coeff (Global)	0.500	Run Time (mins)	60
Foul Sewage per hectare (l/s)	0.000	Output Interval (mins)	1
Number of Input Hydrographs	0	Number of Storage Structures	1
Number of Online Controls	1	Number of Time/Area Diagrams	0
Number of Offline Controls	0	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FSR	Profile Type	Summer
Return Period (years)	30	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	20.400	Storm Duration (mins)	30
Ratio R	0.428		


Mott MacDonald		Page 3
1st Floor Spring Bank House 33 Stamford Street Altrincham WA14 1ES		
Date 17/08/2016 15:50 File TWICKENHAM EXISITNG SW ...	Designed by sim64626 Checked by	
Micro Drainage		Network 2015.1

Online Controls for Existing

Pump Manhole: E15, DS/PN: E1.011, Volume (m³): 6.3

Invert Level (m) 5.730

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	24.0000	1.200	24.0000	3.000	24.0000	7.000	24.0000
0.200	24.0000	1.400	24.0000	3.500	24.0000	7.500	24.0000
0.300	24.0000	1.600	24.0000	4.000	24.0000	8.000	24.0000
0.400	24.0000	1.800	24.0000	4.500	24.0000	8.500	24.0000
0.500	24.0000	2.000	24.0000	5.000	24.0000	9.000	24.0000
0.600	24.0000	2.200	24.0000	5.500	24.0000	9.500	24.0000
0.800	24.0000	2.400	24.0000	6.000	24.0000		
1.000	24.0000	2.600	24.0000	6.500	24.0000		

Mott MacDonald		Page 4
1st Floor Spring Bank House 33 Stamford Street Altrincham WA14 1ES		
Date 17/08/2016 15:50 File TWICKENHAM EXISITNG SW ...	Designed by sim64626 Checked by	
Micro Drainage		Network 2015.1

Storage Structures for Existing

Tank or Pond Manhole: E15, DS/PN: E1.011

Invert Level (m) 5.530

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	84.0	2.000	84.0	2.601	0.0
1.000	84.0	2.600	84.0		

100 year Return Period Summary of Critical Results by Maximum Flood Volume
(Rank 1) for Existing

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m ³ /ha Storage	2.000
Hot Start Level (mm)	0	Inlet Coeffiecient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs	0	Number of Storage Structures	1
Number of Online Controls	1	Number of Time/Area Diagrams	0
Number of Offline Controls	0	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.431
Region England and Wales	Cv (Summer)		0.750
M5-60 (mm)	20.700	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm)	300.0
Analysis Timestep	2.5 Second Increment (Extended)
DTS Status	OFF
DVD Status	ON
Inertia Status	ON

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440, 2160, 2880, 4320, 5760, 7200, 8640, 10080
Return Period(s) (years)	100
Climate Change (%)	30

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surchage	First (Y) Flood	First (Z) Overflow	Overflow Act.
E1.000	E1	240 Winter	100	+30%	100/15 Summer	100/15 Summer		
E1.001	E2	240 Winter	100	+30%	100/15 Summer	100/15 Summer		
E1.002	E3	15 Winter	100	+30%	100/15 Summer	100/15 Summer		
E1.003	E4	240 Winter	100	+30%	100/15 Summer	100/15 Summer		
E1.004	E5	240 Winter	100	+30%	100/15 Summer	100/15 Summer		
E1.005	E6	180 Winter	100	+30%	100/15 Summer	100/15 Summer		
E1.006	E7	180 Winter	100	+30%	100/15 Summer	100/15 Winter		
E1.007	E8	30 Winter	100	+30%	100/15 Summer	100/30 Winter		
E1.008	E9	60 Winter	100	+30%	100/15 Summer	100/30 Winter		
E1.009	E10	30 Winter	100	+30%	100/15 Summer	100/30 Summer		
E1.010	E11	30 Winter	100	+30%	100/15 Summer	100/30 Winter		
E2.000	E15	120 Winter	100	+30%	100/15 Summer	100/30 Summer		
E2.001	E16	60 Winter	100	+30%	100/15 Summer	100/30 Summer		
E3.000	E15	120 Winter	100	+30%	100/15 Summer	100/15 Summer		
E3.001	E16	120 Winter	100	+30%	100/15 Summer	100/30 Winter		
E3.002	E17	360 Winter	100	+30%	100/15 Summer			
E3.003	E18	60 Winter	100	+30%	100/15 Summer	100/30 Winter		

100 year Return Period Summary of Critical Results by Maximum Flood Volume
(Rank 1) for Existing

PN	US/MH Name	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m ³)	Flow / Cap.	Overflow (l/s)	Pipe Flow (l/s)	Status	Level Exceeded
E1.000	E1	9.199	0.484	19.262	0.45		14.1	FLOOD	19
E1.001	E2	9.200	0.460	20.472	0.14		14.9	FLOOD	19
E1.002	E3	9.207	0.657	6.654	0.58		35.7	FLOOD	10
E1.003	E4	9.210	0.790	60.265	1.21		31.4	FLOOD	20
E1.004	E5	9.217	0.752	67.109	1.09		44.0	FLOOD	20
E1.005	E6	9.223	0.782	72.600	1.36		75.8	FLOOD	20
E1.006	E7	9.232	0.762	41.927	0.41		85.2	FLOOD	16
E1.007	E8	9.243	0.913	0.259	1.16		196.2	FLOOD	1
E1.008	E9	9.301	1.041	0.143	1.26		188.6	FLOOD	1
E1.009	E10	9.301	1.151	11.187	2.09		242.7	FLOOD	10
E1.010	E11	9.333	1.198	3.567	0.97		245.9	FLOOD	7
E2.000	E15	9.303	0.928	23.462	1.28		15.1	FLOOD	14
E2.001	E16	9.310	0.890	9.849	0.38		51.1	FLOOD	12
E3.000	E15	9.325	0.740	35.285	0.44		20.5	FLOOD	16
E3.001	E16	9.337	0.877	7.188	0.48		30.8	FLOOD	9
E3.002	E17	9.317	0.957	0.000	0.24		17.9	FLOOD RISK	
E3.003	E18	9.351	1.021	0.568	0.76		102.6	FLOOD	3

100 year Return Period Summary of Critical Results by Maximum Flood Volume
(Rank 1) for Existing

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surchage	First (Y) Flood	First (Z) Overflow	Overflow Act.
E3.004	E19	60 Winter	100	+30%	100/15 Summer	100/30 Winter		
E2.002	E15	360 Winter	100	+30%	100/15 Summer			
E1.011	E15	30 Winter	100	+30%	100/15 Summer	100/30 Winter		
E1.012	E16	360 Winter	100	+30%	100/15 Summer			

PN	US/MH Name	Water Surcharged			Flooded		Pipe		Level Exceeded
		Level (m)	Depth (m)	Volume (m ³)	Flow / Cap.	Overflow (l/s)	Pipe Flow (l/s)	Status	
E3.004	E19	9.338	1.128	7.938	0.79		126.5	FLOOD	9
E2.002	E15	9.297	1.217	0.000	0.22		42.5	FLOOD RISK	
E1.011	E15	9.333	3.653	0.094	1.27		24.0	FLOOD	4
E1.012	E16	8.228	0.095	0.000	1.83		24.0	SURCHARGED	