



New Café Kitchen Ventilation Proposals within Existing Coach House

Site:

English Heritage
Marble Hill House
Richmond Road
Twickenham
London
TW1 2NL

August 18, 2018

Table of Contents

| | |
|---|----------|
| Introduction | 3 |
| DEFRA Risk Assessment Summary..... | 3 |
| Completed Risk Assessment..... | 3 |
| Proposals..... | 6 |
| APPENDICES | 7 |

- 01 Ventilation diagram and distance of receptors
- 02 Proposed kitchen plans with equipment
- 03 Proposed ventilation canopy and UV filtration
- 04 Proposed Fans

Introduction

The existing Coach House Café is currently leased by English Heritage to an independent operator. The proposed new cafe will be run in house and operated directly by English Heritage Catering. The new café is to be located in the existing coach house using the same areas for kitchen and servery and with an additional overflow seating area. The menu offer will include hot food and freshly baked products. It will not include griddled, char grilled or deep fried products.

English Heritage want to minimize any potential nuisance from odour and noise to neighbour's and homes adjacent to the facility and have prepared this document to inform the council of their approach and proposals.

DEFRA Risk Assessment Summary

Defra have a document entitled 'Guidance on the Control of Odour and Noise from Commercial Kitchen Exhaust Systems.' It describes a method of risk assessment for odour, guidance on minimum requirements for odour and noise control, and advice on equipment selection.

Completed Risk Assessment

| Section 1 – Background Information | |
|---|--|
| 1.1 Contact Details – tell us who we need to contact for further information | <p>Name <i>Simon C. Colley</i></p> <p>Position <i>Catering Consultant</i></p> <p>Tell Number <i>01424 422 784</i></p> <p>E-Mail <i>simon@cooper8.co.uk</i></p> <p>Address <i>2nd Floor 7 Cambridge Road Hastings, East Sussex TN34 1DJ</i></p> |

| | |
|---|--|
| 1.2 Proposed Hours of Operation | <i>The new café will be open 7 days a week between 09:00 to 18:00 during main season and 09:00 to 16:00 during winter season. In addition to these opening times, a facility will be provided to allow takeaway teas and coffees to be served before 9am through a serving hatch</i> |
| 1.3 Type of Food to be served / Type of Catering Done | <i>Tea Shop / Café with Functions</i> |
| 1.4 Kitchen Equipment to be used in the commercial kitchen | <i>Cooking Pots / Bains Marie / Steam Oven / Oven Ranges/ Electric Salamander</i> |

| | |
|---|--|
| 2.1 Stack Dispersion – all commercial kitchens must have a chimney stack to expel odours from the kitchen. Please provide us with information on the stack you use / intend to use at your site. | Stack Height – in metres <i>N/A, Ventilation horizontal at roof level</i> |
| | Efflux Velocity – in meters per second <i>2.5</i> |
| | Will the stack be fitted with a plate cap or cowl? <i>A louvered grill</i> |
| Notes: | |
| <ol style="list-style-type: none"> <i>Stack Height – this should be in meters above ground level</i> <i>Efflux Velocity – this is the term used for how fast air is expelled from your stack. Your equipment supplier should be able to provide these details</i> <i>Fitting any kind of restriction at the opening of a stack is bad practice as it hinders the dispersion of odours. Many alternative duct terminators are available to address this</i> | |
| 2.2 Diagram | <i>Drawings attached – Appendix 01</i> |

| Section 2 – Risk Assessment | | | |
|--------------------------------------|-----------|-------|---|
| Criteria | Score | Score | Details |
| Dispersion | Very Poor | 20 | Low level stack discharge, discharge into courtyard of restriction on stack |
| | Poor | 15 | Not low level but below eaves, or discharge at below 10 m/s |
| | Moderate | 10 | Discharging 1m above eaves at 10 – 15 m/s |
| | Good | 5 | Discharging 1m above ridge at 15 m/s |
| Dispersion – score for your premises | 15 | | |
| Proximity of receptors | Close | 10 | Closest sensitive receptor less than 20m from kitchen discharge |
| | Medium | 5 | Closest sensitive receptor between 20 – 100m from kitchen discharge |
| | Fair | 1 | Closest sensitive receptor more than 100m from kitchen discharge |

| | | | |
|--|-----------|----|--|
| Size of Kitchen | Large | 5 | More than 100 covers or large sized take away |
| | Medium | 3 | Between 30 – 100 covers or medium sized take away |
| | Small | 1 | Less than 30 covers or small take away |
| Size of kitchen – score for your premises | 5 | | |
| Cooking Type (odour and grease loading) | Very High | 10 | Pub (high level of fried food), fried chicken, burgers or fish and chips |
| | High | 7 | Kebab, Vietnamese, Thai or Indian |
| | Medium | 4 | Cantonese, Japanese or Chinese |
| | Low | 1 | Most pubs, Italian, French, Pizza or steakhouse |
| Cooking type – score for your premises | 1 | | |
| Add up the scores for the four different sections and write the total in the box below | | | |
| TOTAL SCORE | 26 | | |

The risk assessment score is used to see if you require low, high or very high level odour control.

| Impact Risk | Odour Control Requirement | Score |
|---------------|-------------------------------|--------------|
| Low to Medium | Low level odour control | Less than 20 |
| High | High level odour control | 20 to 35 |
| Very High | Very high level odour control | More than 35 |

Section 3 – Odour Control

Refer to Appendix 03 for drawing representation of proposed ventilation canopy and UV filtration.

Section 4 – Maintenance

Any system will deteriorate over time, it is important that you have a plan to maintain the equipment that you have installed to retain its effectiveness. Guidance on the maintenance of kitchen extraction equipment and odour abatement plant is contained in the DEFRA Guidance on pages 76-80, further information should also be available from your supplier. Use the space below to explain how you intend to maintain the installed system.

Grease drawers and filters cleaned on a weekly basis.
 Fans and UV filtration checked on a 6 monthly basis.
 UV tubes changed as required and to manufacturer's literature.
 Ductwork cleaning as required, checked on a 12 monthly basis.

Section 5 – Noise

Due to the fact that commercial kitchen extraction equipment is often operated at sensitive times it is important that they are designed to be as quiet as possible.

5.1 What is the predicted noise level to be emitted by your kitchen extract fan in dB (A)

Extract fan dBA = 47 less attenuation
15dBA = approx 32 dBA

Note:

The noise level of your fan is something that your supplier should be able to provide you with. The noise level will either be a sound power level or Lw in dB or it will be a sound pressure level or Lp at a stated distance e.g. 60dB @ 1m. Please append any specification you have for the fan to this report.

Proposals

The risk score is 26 and indicates the need for a high level of odour control. Although the type of catering is of a *low risk*, the extract duct will discharge below 10m. This is to avoid the visibility of any ventilation stack height rising above the building and to reduce any visibility from the neighbouring houses.

To mitigate nuisance, we are proposing to use a Jevens UV Hood that has turbo-swing filters within the canopy. The separation rate at the swing filters is 90 to 95% and with the effect of UV photolysis / ozonolysis the odour removal rate will be 95-99% and constitutes a high level of odour control.

See proposed plans and equipment in Appendices.


APPENDICES

01 Ventilation diagram and distance of receptors


02 Proposed kitchen plans with equipment

03 Proposed ventilation canopy and UV filtration


04 Proposed Fans





ELEVATION E-E



ELEVATION F-F



PLAN VIEW: KITCHEN



Jevern

STATUS
APPROVAL

| DESCRIPTION | REV | DATE |
|-------------|-----|------|
| | | |

COOPER8 LTD
2ND FLOOR, 7 CAMBRIDGE ROAD
MADISON, LAIN 2020K, NOLA, US
TEL: +1 504 835 6774
WWW.COOPER8.COM

CLIENT
ENGLISH HERITAGE

PROJECT
MARBLE HILL ENGLISH HERITAGE

DRAWING
NEW KITCHEN VENTILATION SYSTEM

SCALE
1:30@A1


DATE
JULY 2018

JOB NO
CV18-895

DWG NO
001

COPYRIGHT
This drawing is copyright and issued to you in confidence. It must not be copied, reproduced, or otherwise used without the prior written permission. It remains the property of COOPER8 LTD and must be returned on completion of the project. All dimensions are in millimeters unless stated otherwise. If in doubt ask. Do not scale from the drawing.

DRAWING INFORMATION
Drawing No: CV18-895-001
The CAD Drawing contains the following XREFs:



EQUIPMENT SCHEDULE

| | | | |
|-------|---------------------------------------|-------|---|
| 01 | INSECT CONTROL UNIT | 34 | HOT CUPBOARD |
| 02 | DIRTIES RACKING | 35-36 | UNDERCOUNTER HOTCUPBOARD |
| 03 | WASTE BIN (x3) | 37 | ST/STL WALL TABLE WITH HEATED GANTRY OVER |
| 04 | INLET TABLING | | |
| 05 | HOOD TYPE DISHWASHER | 38 | RISE AND FALL GRILL |
| 06 | OUTLET TABLING | 39 | 6-BURNER OVEN |
| 07 | GREASE DOSING SYSTEM | 40 | ST/STL WALL TABLE WITH DRAWER |
| 08 | MOBILE RACK | 41 | 10-GRID COMBINATION OVEN |
| 09 | MOBILE RACK | 41a | STAND |
| 10 | 20H MAKER | 42 | CONVECTION OVEN |
| 11 | MOBILE STAND FOR MIXER | 42a | STAND |
| 12 | ST/STL WALL TABLE | 43 | SERVICES DISTRIBUTION UNIT |
| 13 | INGREDIENT BINS (x3) | 44 | CANOPY |
| 14 | ST/STL WALL TABLE WITH COOLING RACKS | 45-49 | SPARE NO. |
| 15-19 | SPARE NO. | 50 | COUNTER |
| 20 | PREP TABLING WITH INSET SINK | 51 | MULTI-TIER |
| 21 | UNDERCOUNTER REFRIGERATOR | 52 | CLIENT SUPPLY: TILL UNIT |
| 22 | WALL TABLE | 52a | TILL SCREEN |
| 23 | REFRIGERATED DRAWERS WITH BLAST CHILL | 53 | BACK BAR |
| 24 | UPRIGHT REFRIGERATOR | 54 | CLIENT SUPPLY: GRINDER |
| 25 | UPRIGHT FREEZER | 55 | SPARE NO. |
| 26 | ST/STL WALL TABLE | 56 | UNDERCOUNTER REFRIGERATOR |
| 27 | ST/STL WALL TABLE | 57 | WASTE BIN |
| 28 | COUNTER REFRIGERATOR | 58 | CLIENT SUPPLY: COFFEE MACHINE |
| 29 | SALADETTE UNIT | 59 | WATER BOILER |
| 30 | ST/STL WALL SHELF | 60 | INSET SOUP WELL |
| 31 | PREP TABLING WITH INSET SINK | 61 | ICE CREAM CONSERVATOR |
| 32 | WASH HAND BASIN | 62 | CONDIMENT UNIT |
| 33 | ST/STL WALL SHELF | 63 | MICROWAVE |
| | | 64 | BABY WARMING (NOT SHOWN) |

NOTES

| | | | |
|--------------------|--------------|-----|-------|
| REV: | DESCRIPTION: | BY: | DATE: |
| PLAN LAYOUT | | | |

Cooper8 Ltd

COOPER8 LTD
 2nd FLOOR, 7 CAMBRIDGE ROAD
 HASTINGS, EAST SUSSEX, TN34 1DJ

Tel: +44 (0)1424 422 784
 Email: jiron@cooper8.co.uk
 Web: www.cooper8.co.uk

CLIENT:

ENGLISH HERITAGE

SITE:
 MARBLE HILL
 COACH HOUSE

TITLE:
 KITCHEN AND SERVERY
 LAYOUT

| | | | |
|--------------|-------------|-----------|----------|
| SCALE AT A3: | DATE: | DRAWN: | CHECKED: |
| 1:50 | 23/07/18 | GLC | SC |
| PROJECT NO: | DRAWING NO: | REVISION: | |
| CO_121 | CO-121-001 | - | |

Jeven

Top ventilation for top chefs

Supply air hood JSI-UV-Turbo





Table of Contents

| | |
|------------------------------------|----|
| Product description, Product code | 3 |
| Functioning principle, Parts | 4 |
| Dimensions | 5 |
| Positioning, Design Service | 6 |
| Exhaust air | 7 |
| Pressure loss and sound data | 7 |
| Supply air | 8 |
| Supply air distribution, Lights | 9 |
| Electrical and automation planning | 10 |

We want to help you in design of ventilation by offering Jeven designer service to your disposal.


Design Service helps in design and makes unique proposal solution with Jeven products.

Contact us: jeven@jeven.fi
010 231 2030

Supply Air Hood JSI-UV-Turbo


FUNCTIONING PRINCIPLE

1. Dirty air rises due to temperature differences against the ceiling of the hood.
2. Dirty air is exhausted immediately through the TurboSwing unit.
3. Since TurboSwing's air intake is placed close to the ceiling, the warmest dirty air is always exhausted through it. Ventilation efficiency is of the highest rate because of the correct position of TurboSwing with respect to the kitchen equipment.
4. Direction air prevents leakage and directs steam and impurities towards TurboSwing.
5. Fresh and draught-free supply air is brought into the kitchen through the supply air columns placed on the outside walls of the supply air hood. This results in very effective ventilation in the kitchen.
6. The purified air flows in the catalyst-coated chamber where UV-light transforms remaining grease to carbon dioxide and water. Clean air is exhausted into the ducts.



PARTS



1. Outer casing
2. Supply air connection and damper unit
3. Light fixture with cable
4. UV-TurboSwing filter unit
5. Direction air unit with measurement tap for the supply air
6. Exhaust air connection and damper plate
7. Personal supply air nozzle
8. Supply air unit
9. Ceiling console
10. Hanging bracket





Supply Air Hood JSI-UV-Turbo

DIMENSIONS

Wall hood



Island type hood



Supply Air Hood JSI-UV-Turbo


POSITIONING

The size of the canopy is determined by the size of the kitchen equipment. The overhang depends on the type of equipment and the distance between the hood and the equipment.

For this type of equipment, the overhang should be at least 300 mm.

The typical distance between the hood side and the floor is 2100-2200 mm.

If the equipment has any doors that open upwards, make sure there is enough distance to the canopy.




DESIGN SERVICE

Jeven Design Service helps you choose the best solution for your professional kitchen project.

Simply email us a drawing of the kitchen lay-out and a list of the cooking equipment to jeven@jeven.fi


We will do all the calculations and prepare all the necessary drawings of the canopies.

This service is always free of charge to you.



Supply Air Hood JSI-UV-Turbo

EXHAUST AIR




Recommended exhaust flow / spigot


| Spigot size ø mm | Exhaust flow | | Pressure loss Pa |
|---------------------|--------------|-------------------|---------------------|
| | l/s | m ³ /h | |
| 315 | 100-200 | 360 - 720 | 20 - 60 |

PRESSURE LOSS AND SOUND DATA

TurboSwing 750 rpm



TurboSwing 1100 rpm



Sound power level L_w in each octave band is computed by adding the corresponding factor, Kok to the sound power level L_pA . $L_w = L_pA + Kok$.

Factor, Kok

| Hz | 125 | 250 | 500 | 1000 | 2000 | 4000 |
|------|-----|-----|-----|------|------|------|
| Kok | 7 | -1 | -5 | -5 | -7 | -6 |
| tol. | ±3 | ±3 | ±2 | ±2 | ±3 | ±4 |

Supply Air Hood JSI-UV-Turbo

SUPPLY AIR



The canopies are supplied from the factory with suitable air flow rates for a pressure level of 25-35 Pa.

| Hood height | Supply air unit width | |
|-------------|-----------------------|-------------|
| mm | 200 mm | 500 mm |
| 330 | - | 50-90 l/s |
| 540 | 40-70 l/s | 100-150 l/s |


PRESSURE LOSS, SOUND DATA & THROW LENGHT / SUPPLY AIR UNIT

Spigot \varnothing 200 mm. Unit width 500 mm. Hood height 330 mm.

Spigot \varnothing 160 mm. Unit width 200 mm. Hood height 540 mm.



Spigot \varnothing 250 mm. Unit width 500 mm. Hood height 540 mm.



Spigot \varnothing 200

| Hz | 125 | 250 | 500 | 1000 | 2000 | 4000 |
|------|---------|---------|---------|---------|---------|---------|
| Kok | -2 | 7 | 4 | -5 | -19 | -26 |
| tol. | ± 6 | ± 4 | ± 2 | ± 2 | ± 3 | ± 5 |

Spigot \varnothing 160

| Hz | 125 | 250 | 500 | 1000 | 2000 | 4000 |
|------|---------|---------|---------|---------|---------|---------|
| Kok | -2 | 1 | 2 | 1 | -7 | -16 |
| tol. | ± 3 | ± 3 | ± 2 | ± 2 | ± 3 | ± 4 |

Spigot \varnothing 250

| Hz | 125 | 250 | 500 | 1000 | 2000 | 4000 |
|------|---------|---------|---------|---------|---------|---------|
| Kok | 6 | 8 | 4 | -5 | -10 | -18 |
| tol. | ± 3 | ± 3 | ± 2 | ± 2 | ± 3 | ± 4 |

The sound power level (Lw) in each octave band is computed by adding the corresponding factor Kok to the sound pressure level (LpA), as in $Lw = LpA + Kok$