

AECOM Limited AECOM House 63-77 Victoria Street St Albans Hertfordshire AL1 3ER United Kingdom

T: +44(0)1727 535000 aecom.com

Project name: Red & Yellow Specialist Extra Care - Melliss Avenue, Kew

Project ref: 4617

From: Robert Murphy and Colin Page, AECOM

Date: 7<sup>th</sup> June 2019

# **Re: GLA Energy Strategy Review**

Following the submission of planning application (London Borough of Richmond upon Thames reference 18/3310/FUL, GLA Case Number 4617) for the redevelopment by our client, Melliss Ave Devco Limited, of the former Kew Biothane Plant on Melliss Avenue in Kew, we were pleased to receive comments from the GLA's Case Officer, Kate Randall, dated 14/11/18 on the Energy Strategy, which broadly confirmed that *the Energy Hierarchy has been followed* and *the proposed strategy is generally supported*. This aligns with feedback received from LBR's appointed energy consultant (Climate Integrated Solutions) confirming that the proposed energy and sustainability strategy was in compliance with the appropriate policy. Indeed, a number of the comments raised by the GLA were the same as those identified by CIS and therefore the responses and supplementary information provided below are identical to those provided to, and subsequently accepted by, CIS.

We have listed in the table below the comments from the Case Office, alongside our response, with supplementary information provided at the end of the table where required.

Further comments have been received in an email dated 21<sup>st</sup> December 2018 (from Robbie Thompson to Kate Randell of the GLA), but only received by the client team on 1<sup>st</sup> May 2019 (emailed by Hannah Thomas of the GLA to Marlon Deam of DP9, the client's planning consultant); these new comments have been added to the table below in red text, alongside an initial response from the client's designers. Closed items are indicated in green text.

After further review by the GLA team (Robbie Thompson, via email to Hannah Thomas on 22/05/2019, subsequently forwarded on to DP9), the principle of an ambient temperature loop has been agreed as appropriate for this scheme, subject to provision of further information. This pragmatic approach is welcomed by the applicant, and the requested information has been provided in the table below. As before, the most recent GLA comments and client team responses have been added to the table, this time in blue text. As before, closed items are indicated in green.

GLA Comment	AECOM Response November 2018	GLA Comments 1 <sup>st</sup> May 2019	Client Team Response May 2019	GLA Comments 22 <sup>nd</sup> May 2019	Client Team Response June 2019
1. The Energy Hierarchy has been followed; the proposed strategy is generally supported; however, the applicant should submit additional information to ensure compliance with the London Plan policies.	Agreed	-	Closed	-	Closed
2. The applicant is encouraged to use the GLA's Carbon Emission Reporting spreadsheet, which has been developed to allow the use of the updated SAP 10 emission factors alongside the SAP 2012 emission factors. The link to the spreadsheet can be found here: https://www.london.gov.uk/what- we-do/planning/planning- applications-and-decisions/pre- planning-application-meeting- service-0. This is encouraged to be submitted for review.	The impact of the changing carbon factors was considered in the submitted Energy Strategy (section 7), for precisely the reasons identified here, which shows a significant improvement in the carbon performance. We have downloaded the GLA spreadsheet and attempted to enter the necessary figures into it. However, there appear to be a number of errors and the spreadsheet is (deliberately) locked to prevent us from amending it. As an example, the all-electric non-domestic building's carbon is only dropping from 17kg/m <sup>2</sup> to 15kg/m <sup>2</sup> . We understand that an updated version of the spreadsheet may be being prepared and therefore we propose waiting for this. The qualitative impact of the	No further action until spreadsheet has been updated.	Agreed.		

	revised carbon factors is already considered in the project Energy Strategy, showing the further benefits of the proposed energy strategy if these were deemed to apply to this project.				
<b>BE LEAN</b> 3. A range of passive design features and demand reduction measures are proposed to reduce the carbon emissions of the proposed development.	Agreed	-	Closed	-	Closed
CO2 and Energy Performance Domestic 4. The domestic element development is estimated to achieve a reduction of 2.3 tonnes per annum (2.1%) in regulated CO2 emissions compared to a 2013 Building Regulations compliant development. The applicant should note that the new draft London Plan includes a target of a 10% improvement on 2013 Building Regulations from energy efficiency which applicants should be aiming towards. The applicant should therefore model additional energy efficiency measures and commit to higher carbon savings through energy efficiency alone.	This query is a new one (i.e. not previously requested by LBR in their comments). We understand that it forms part of the emerging GLA policy but may not be specifically applicable to this project by virtue of the date when it was submitted. The building performance has been optimised as far as practicable, especially considering the specific requirements of the occupants (e.g. large glazed areas to promote natural daylight, wellbeing and recovery). For example, we did model the impact of higher performance glazing (lower g values), which did reduce the	Be Lean has been at the top of the GLA energy hierarchy for several years and therefore to be prioritised. The savings the applicant has achieved suggests that this part of the hierarchy has not been prioritised. The applicant is required to model further energy efficiency measures. Item is still outstanding.	We would dispute this, as significant efforts were made to meet and improve upon the compliant building using "be lean" measures alone. At this stage, delivering further improvements through the building form and fabric would likely have a significant impact on the massing and architectural look of the building, which is not something the client would wish to pursue. We would also add that further reductions in the U-values would lead to increases in the cooling loads and risk of overheating, which we would wish to avoid for obvious reasons.	The applicant disputes that additional improvement are required in Be Lean and they would lead to impact on massing and architectural look and increases in cooling load, however, no quantitative assessment appears to have been undertaken showing the impact of these issues as such the requirement still stands and further improvement to fabric energy efficiency is required.	To substantiate the previous statement, further modelling has been undertaken. If the g-value is altered from the current figure of 0.45 (a high- performing solar control glass) to a value of 0.72 (glass without a coating), the improvement from "be Lean" would increase from 2.1% to 8.3%, however the apartments would suffer from unacceptable overheating. This is undesirable for a number of obvious reasons, especially considering the elderly nature of residents. Overheating is a particular concern for older residents. Older people are at an increased risk of heat related illness, especially if their health is already deteriorating. They are usually less able to adapt to higher temperatures. In addition older people will often be at home for most of the day and therefore exposed to peak day temperatures within their housing development.

	heating load but had a corresponding negative impact on overheating and cooling requirements; the current proposal is, in our view, a sensible compromise – especially considering an overall 35% improvement is achieved taking all measures into account.			As there is no aspiration to introduce cooling to the apartments (with the corresponding increase in overall carbon dioxide emissions), we believe the current proposal – using a solar control glass to achieve a sensible balance between beneficial heating whilst avoiding overheating – which may not achieve the consultation GLA proposed 10% improvement for the Be Lean Case, but does achieve the overall 35% improvement – is a proportionate approach.
5. The applicant has provided the 'be lean' DER and TER output sheets from the modelling software; however these are not labelled. The applicant should provide and clearly label DER and TER output sheets for each stage of the energy hierarchy. The applicant should provide a summary table showing all apartments TER and DERs and how the overall development carbon emissions have been calculated.	This is similar to a query raised by CIS for LBR and therefore we can respond quickly (we previously provided additional tables with results in our response to LBR, which is also attached for information to this response to the GLA comments) The split between residential and non-residential units is included as figure 6.1 in the energy strategy report (also included in the supporting information below this table), which shows the baseline, be lean, be clean and be green figures. Individual values have been provided for each of the sample dwellings – see	Documents provided. No further action required.	Closed	Closed

Non-domostic	supporting information below this table. The TER worksheets for each sample apartment at each stage (baseline, be lean, be clean) have also been provided separately.				
Non-domestic 6. The non-domestic element of the proposed development is estimated to achieve a reduction of 5.3 tonnes per annum (5.7%) in regulated CO2 emissions compared to a 2013 Building Regulations compliant development. The applicant should note that the new draft London Plan includes a target of a 15% improvement on 2013 Building Regulations from energy efficiency which applicants should aim towards. The applicant should therefore model additional energy efficiency measures and commit to higher carbon savings through energy efficiency alone.	This query is a new one (i.e. not previously requested by LBR in their comments). We understand that it forms part of the emerging GLA policy but may not be specifically applicable to this project by virtue of the date when it was submitted. The building performance has been optimised as far as practicable, especially considering the specific requirements of the occupants (e.g. large glazed areas to promote natural daylight, wellbeing and recovery). For example, we did model the impact of higher performance glazing (lower g values), which did reduce the heating load but had a corresponding negative impact on overheating and cooling requirements; the current proposal is, in our	See response to item 4 above. Item still outstanding	Similar to item 4 above – we do not believe that achieving a 15% reduction through energy efficiency for the non-domestic elements is possible without fundamentally affecting the look and feel of the building. In addition, it may lead to unintended consequences, including additional cooling requirements or overheating. We would reiterate the earlier point that the <i>requirement</i> to achieve the additional improvement (beyond Building Regulations compliance) through energy efficiency was not in place at the time of preparing and submitting the application.	See response to item 4 above. Further consideration of energy efficiency measures is required. Item is still outstanding	Similarly to the domestic areas (point 4 above), we do not believe there is merit in worsening the performance of the glazing in the non-domestic elements of the project (ground floor) to increase the % improvements from energy efficiency measures alone towards the 15% targeted in the draft London Plan that wasn't applicable at the time of design. The overall impact on the project of this – in terms of total carbon emissions, extent of overheating, resident health and wellbeing etc – would be counterproductive. However, for the ground floor areas we have also explored other alternatives to achieving further improvements. Through a combination of introducing a shading canopy to the restaurant (shown in the supporting evidence below this table), reducing the specific fan power of the AHUs serving ground floor to 1.4W//s and specifying higher performance pumps with variable speed control, we can achieve an 8.5% reduction from energy efficiency alone, up from 5.6%.
	,				

	<ul> <li>especially considering an overall 35% improvement is achieved taking all measures into account.</li> </ul>				welcomed, especially given that the 15% target is not fully applicable to this project.
7. The applicant has provided the 'be lean' BRUKL sheets from the modelling software. The applicant should confirm that the boiler efficiency used in the 'Be Lean' assessment is the same as the boiler efficiency for the notional building.	Confirmed – an SCOP figure of 91% has been assumed, which is in line with the guidance – see supporting information below this table for further information,	This doesn't fit with the supplied BRUKL sheet that suggests that 0.96 was used.	The figure shown on the BRUKL sheet is the "nominal" efficiency of the boiler. This is not otherwise used in the calculation and we can easily change it to match the 91% seasonal efficiency that is actually used in the calculations.	Applicant confirmed that 91% has been used. No further information is required.	Closed
Energy Demand and Fabric Energy Efficiency 8. In line with the latest GLA guidance the applicant should report the overall Part L Fabric Energy Efficiency (FEE) performance of the development for both the baseline and the 'be lean' stages of the energy hierarchy in MWh/year and kWh/m2. The percentage of improvement (%) should also be provided.	This additional information is provided in the supporting evidence below this table, noting again that the energy strategy was prepared in accordance with an earlier version of the GLA guidance.	Details supplied no more information required.	Closed	-	Closed
<b>Cooling and Overheating</b> 9. The demand for cooling and the overheating risk will be minimised through improved g- values, extract ventilation and solar shading.	Agreed	-	Closed	-	Closed
<b>Domestic</b> 10. A Dynamic Overheating Analysis has been undertaken to assess the overheating risk within the dwellings using the CIBSE TM59 methodology and the London Design Summer Year 1 (DSY1) weather file: 2020s, High emission, 50% percentile scenario, this is welcomed.	Agreed	-	Closed	-	Closed

11. The results show that the design proposals are anticipated to meet the CIBSE	Agreed	-	Closed	-	Closed
recommendations for comfort.					
assuming natural ventilation i.e.					
occupants can open the windows.					
12. The applicant is required to	This is similar to a query	Modelling should be	This modelling could be	See response 19, no further	Closed
assess a sample of corridors to	raised by CIS for LBR - we	undertaken once flow and	undertaken, but there was no	information is required.	
ensure no overheating occurs.	responded to CIS that:	return temperatures have	reason to do it previously as there		
	Overheating assessment is	be finalised Item still	is no hot pipework running in the		
	normally only required in	outstanding.	corridors that would contribute to		
	communal corridors where		overheating. This is one of the		
	communal heating systems		benefits of the proposed low		
	run through them; given the		temperature ambient heat loop.		
	proposed operating				
	temperatures of the ASHP		We suggest the need for modelling		
	system (at ambient		is determined once the principles		
	temperatures of 15-20°C),		of a low temperature ambient loop		
	this is not considered		are accepted (or otherwise).		
	applicable here and				
	therefore overheating of				
	corridors has not been				
	assessed.				
Non-domestic	This is similar to a query	The GLA Cooling Hierarchy	To be discussed further.	Applicant suggests that it is	Our residents will be elderly such that
13. The area weighted average	raised by CIS for LBR - we	requires that passive		not practical to reduce	eligibility restrictions agreed through
(MJ/m2) and total (MJ/year)	responded to CIS that:	measures are used first to	Whilst we recognise the reasons	cooling energy demand to	the S106 agreement will determine
notional building has been	As can be seen from the IES	reduce mechanical	behind pushing for lower cooling	below the notional. While it is	that the purchaser will be over 65 and
provided but the actual building's	diagram included in the	cooling, if it is required.	loads, this is particularly difficult for	accepted that reducing	have an existing long term health
cooling demand is higher than the	supplementary information	25% is a significant	this type of building.	cooling demand can be	condition. It is expected that the
notional. The applicant is required	below this table, the majority	increase above the		difficult in certain	majority of residents will be in the age
to model further passive	of non-residential areas at	notional. Further passive	The approach taken in the energy	circumstances, the applicant	range of 75-90.
actual cooling demand is below	ground floor level are cooled	measures should be	strategy followed the principles set	has not adequately	The specialist nature of the extra care
the notional.	- due to the required function	investigated. Item still	out in the guidance applicable at	described why further	development has taken into account
	of the space and the	outstanding.	the time of submission, mainly that	reduction is not possible and	the impact and importance of both
	sensitivity and specific		"If meeting the notional cooling	has not demonstrated that it	natural daylight and heat on residents'
	requirements of the		demand is not possible, the	has reduced the actual	health, wellbeing and therapeutic
	residents.		applicant should provide a clear	cooling requirement as far as	activities.
			explanation of why it is not		

Those spaces without	possible and	outline the	possible. As such item is still	The ground floor needs to optimise
cooling are either	implications for buil	ding design";	outstanding.	natural light in areas predominantly
unoccupied rooms such as	the guidance intro	oduced post-		used by residents, however
plantrooms, risers or stores,	submission has	changed to		compromises have been made
or circulation spaces.	promote further ene	ergy savings,		architecturally and technically to help
	resulting in this reque	est.		balance the energy efficiency.
The actual cooling demand	· ·			
for this building is higher than	We do not believ	e that it is		In addition to the need for natural light,
the notional because of the	practicable to reduc	e the cooling		heat is also a major issue for the
specialist (care)	energy demand for	this special		elderly, particularly in summer months
requirements of the	type of building to	o below the		whereby they are most vulnerable.
occupants of the building. In	notional building.			find it difficult to respond to the
addition to providing cooling	0			extremes and this can lead to heat
in areas which may not				related illness. Getting the right
otherwise need it (to provide				balance between active and passive
respite areas during high				ventilation and cooling has been a
ambient conditions), the				challenge: in both circumstances a
building necessarily features				focus on the resident has been a
areas with high glazing				fundamental consideration.
areas, which are provided at				
around floor level to promote				As part of the design canopies and
well-being, recovery and				shading have been included on the
quality of life for the residents				latest lavouts to the café/restaurant
of this specialist extra care				terrace which is south facing.
development.				g.
				Further to item 6 above, the
The cooling demand is				introduction of the canopy to the
higher in the actual building				restaurant does help somewhat.
than the notional building by				though again the modelling software
25% (as set out in table 4.4				does not accurately reflect this - refer
of the energy strategy).				to the IES results in the supporting
Through the use of efficient				information below this table, which
equipment this reduces to				seem to show only a 0.1% benefit
15% due to the efficient				from the canopy.
cooling equipment used.				In discussion with IES, we have
Cooling accounts for only				identified a work-around to enable the
14% of the regulated CO <sub>2</sub>				true benefit to be included – as per the
emitted from the non-				results at the end of this table, the
			1	

domestic areas (prior to the		difference becomes 22% rather than
reduction associated with		25%.
		We have undertaken further
		interrogation of the IES modelling to
		understand what is driving the
		numbers. In part, this is down to a
		technicality / quirk of the modelling
		software and calculation
		methodology; In uncooled rooms, the
		notional gets 5 ACH of outside air, for
		free, but the actual building does not.
		This usually doesn't matter much, as
		these rooms aren't cooled so the extra
		cooling doesn't make much
		difference. In our building however
		there are little pockets of cooled
		rooms surrounded by uncooled rooms
		which get quite hot (within the model),
		so the extra heat is leaking from the
		uncooled rooms into the cooled rooms
		and causing extra cooling. If one
		changes the entire commercial areas
		to mechanically cooled, the total
		cooling demand increases but the
		notional increases more. So, we could
		actually achieve a 9% reduction in the
		the netional cooling demand compared to
		the hotional cooling demand if we
		specified cooling to all areas of the
		result in overall higher emissions, we
		do not believe this is sepsible /
		responsible
		We are therefore faced with a choice
		between 2 options:

					<ol> <li>having a +22% difference between actual cooling demand and notional cooling demand, but lower overall emissions, or;</li> <li>having a -9% difference between actual cooling demand and notional cooling demand, but higher overall emissions</li> <li>We would be happy to discuss this further with the officer if beneficial, as clearly none of the parties involved want a supposedly green initiative / requirement to lead to additional CO<sub>2</sub> emissions, but we recognise there may be a desire to comply with applicable policies.</li> </ol>
BE CLEAN District beating	Agreed	-	Closed	-	Closed
14. The applicant has carried out an investigation and there is no existing or planned district heating					
networks within the vicinity of the proposed development.					
15. The applicant has provided a	This is similar to a query	Production of indicative	As per the previous response, the	Applicant suggests that	With the principle of an ambient
commitment to ensure that the	raised by CIS for LBR - we	drawings is required and	design has not progressed to this	drawings have yet to be	temperature loop having been agreed,
future connection to a district	responded to CIS that:	should be prioritised. Item	level of detail.	produced. While it is	we have produced a set of indicative
heating network. Drawings		is still outstanding.		accepted that full finalised	block plant layouts - included in the
demonstrating how the site is to	Plant layout drawings have		Appropriate conditions could be	drawing may be not possible,	supporting evidence below this table -
be future-proofed for a connection	not been produced yet, as		proposed to ensure that this future	indicative drawings should	demonstrating, amongst other things,
to a district heating network	the design has not		connection is provided.	still be provided to	how any future district heat network
include space provision for heat	progressed to this stage.			demonstrate that the issue	could be extended to the ground floor
exchangers in the plant room,	To allow for a second to f			nas properly been	neating plantroom.
isolation valves, safe-guarded	IO allow for connection to			considered. Item is still	Manual data and the second second second second
pipe route to the site boundary	any future very low carbon			outstanding	vve would, however, note – and agree
etc.	district heat network, we are				with - the officer's recent comments
	proposing to leave space in				that the likelihood of a suitable DH

the ground floor heating network being available, that would plantroom for future plate itself to the operating lend heat exchangers to be characteristics of the R&Y building - is installed, which could very low and therefore would not building's replace the that physical propose any heating plant. infrastructure / provisions are made primary Suitable valved-off on the site for this connection; we connections would also be have simply indicated how such provided into the main flow pipework may be brought to the and return pipework to allow primary heating plantroom. the secondary LTHW from the PHX to connect into the We do not anticipate any scenario building's heating under which it would be advantageous distribution. considering capital cost, operating cost, resident running cost, energy Due to the consumption and carbon dioxide operating characteristics of emissions - to replace the central the proposed heating system plant and the individual residential (the air source heat pump will heat pumps with a system that worked be selected to deliver the on the likely operating temperatures of primary water loop between a district heating network. Any such 15 to 25), there may be change would only be considered as technical issues with part of a full end-of-life plant replacement strategy - it is therefore connecting in a district heating system, which could only considered appropriate that we potentially require think about a possible pipework route the apartment heat pumps to be at this stage (and build in valved replaced with appropriate connections to the primary pipework heat interface units; the rather than headers), actually feasibility of this would be providing any additional plant or assessed at the time at pipework. which any potential DH system is available. We would further note that the viability of making such a connection will depend not just on the availability,

	reliability, carbon intensity and operating temperatures of the future district heating network, but also on the economic and legal aspects of such a connection, which would need to be considered by the building operator.				
16. The applicant is proposing to install a site-wide ambient temperature heat network. However, the applicant should confirm that all apartments and non-domestic building uses will be connected to the communal heat network.	Agreed - this is the current strategy. All users will be connected to the communal heat network.	-	Closed	-	Closed
17. The applicant should confirm the modelled flow and return temperatures used for the site- wide network.	A notional flow temperature of 15-20 deg has been "modelled" (although we would note that the modelling software does not actually use the flow temperature in the calculations, just the COP efficiency).	Flow and return temperatures will make a huge difference on pumping losses, pipe losses, pipe sizing, overheating and heat pump efficiency. As such it is vital that they are properly understood. The applicant is required to demonstrate each of these issues have been taken into account and detail the methodology used to come up with the flow and return temperatures. Item is still outstanding	The comment is intrinsically linked to the system used – as covered in items 19 and 22 below, if an ambient temperature heating loop with local top up (as currently proposed and modelled) is not acceptable, then there are fundamental changes required to the entire scheme.	See response to 19. Item is still outstanding	Refer to item 19 below.
18. Further information on the floor area, internal layout and location of the energy centre/rooftop plant space should be provided.	Plant layout drawings have not been produced yet, as the design has not progressed to this stage.	Production of indicative drawings is required and should be prioritised. Applicant should know the location and area allocated	The plantroom area is defined on the roof drawing, which has been based on advice from the engineers to the architects on the likely space requirements. Further	-	Refer to item 15 above, as well as the indicative block plant layouts included as supplementary information below this table.

	Sufficient space has been allowed within the plantrooms at ground and roof level for the anticipated plant based on benchmarks and similar projects. Alongside other MEP plant,	for the plant room. Item is still outstanding.	detail is not available until the next stage of design has been completed.		
	final details of the air source heat pumps proposed for the building have not yet been specified and as such only generic information on the performance of the equipment has been identified and used within the energy modelling. However, the team is confident that the allocated areas will be sufficient – detailed design drawings will be produced at				
19. The applicant is proposing to use in-dwelling water source heat pumps to provide adequate temperature to the dwellings. Having multiple small heat pumps does not adhere to GLA energy guidance and therefore the applicant is required to review its approach to heat provision and present a strategy where all heat is provided from a single energy centre.	We believe that the proposed approach is more efficient than a single energy centre supplying heat at the "final" temperature to all apartments. The proposed strategy is to use a centralised air source heat pump system. Temperatures are raised centrally, then distributed to each flat where the temperatures are "topped	The GLA's energy guidance was developed fully aware of each of the points that the applicant raises. While the applicant may believe that it's system is more efficient in theory and practice it not does adhere to GLA's energy guidance. Consideration of a centralised approach is required. Item is still outstanding.	Whilst respecting the officer's opinion, we believe that the ambient temperature loop (supplied by centralised air source heat pumps) topped up by efficient heat pumps in each apartment is appropriate for this building – and delivers significant energy and carbon savings compared to a system where heat is generated centrally from an energy centre and distributed throughout the building at higher temperatures.	Further consideration has been undertaken and given the specific nature of the site it is considered that an ambient temperature system could be acceptable if the applicant is able to demonstrate the following: - The system provides carbon savings beyond a traditional high temperature heat pump system in these circumstances	We appreciate the officer's consideration of the specific nature of this scheme and welcome his acceptance of an ambient temperature system. Further details are included in the supplementary information below this table to address the queries, which we would be happy to discuss at a follow-up meeting should it be beneficial. Information on the approach to any proposed future connection is covered by point 15 above.

	10, where more realistic delivery losses are used. This design seeks to avoid this design intrinsic problem by distributing at lower temperatures, minimizing heat loss. Were the scheme to be assessed under SAP 10 this would be more apparent.				
	The designers have proposed a system which is both efficient in theory and which also have notantial to				
	be efficient in practice.				
<b>BE GREEN</b> 20. The applicant has investigated the feasibility of a range of renewable energy technologies and is proposing to install Photovoltaic (PV) panels and Heat Pumps (etc.).	Agreed	-	Closed	-	Closed
21. A reduction in regulated CO2 emissions of 63.1 tonnes per annum 31.3% will be achieved through this third element of the energy hierarchy.	Agreed	-	Closed	-	Closed
Heat pumps 22. Centralised heat pumps are being proposed in the form of a single centralised system, ambient temperature loop and dwelling heat pump top-up. Further information on the heat pumps should be provided including: a. An estimate of the heating and/or cooling energy (MWh/annum) the heat pumps	This is similar to a query raised by CIS for LBR, but asks for significantly more information – some of which is not available until plant has been selected at a later design and procurement stage. We responded to CIS that:	While the GLA understands that detailed designed have not been finalised, the applicant must be able to demonstrate that its chosen system will work as stated. The applicant still needs to respond to these comments. Where detailed information is not	Refer to Item 19 above – we first need to agree whether the proposed system is acceptable or not, before providing this detailed information at the next stage (post planning) and would welcome appropriate conditions requiring such information to be provided and minimum standards to be exceeded.	See response to 19. Item is still outstanding	Refer also to responses to item 19 above. In addition, we can confirm that: a) The air source heat pump system will provide 100% of the heating and cooling to the development – noting that the annual MWh figures from the Part L Analysis will

would provide to the development	Alongside other MEP plant,	withstanding	assump	tions			be different to the actual
and the percentage of	final details of the air source	backed up	by calcul	ation			annual energy consumption,
contribution to the site's heat	heat pumps proposed for the	and	manufac	turer			for well-known reasons
loads.	building have not vet been	datasheets	should	be			(specially the base
D. Details of now the	specified and as such only	provided.	Item	still			assumptions behind Part L
Performance (SCOP) and	generic information on the	outstanding		•••••			and the way in which
Seasonal Energy Efficiency ratio	performance of the	outotallallig					unregulated loads are
(SEER) has been calculated for	equipment bas been						assumed)
the energy modelling. This should	identified and used within the					b)	Eurthor details of how the
be based on a dynamic	operate modelling					0)	norformance bee been
calculation of the system	energy modening.						performance has been
boundaries over the course of a							modelled are included in the
year i.e. incorporating variations	Primary neating will be						supplementary information
In source temperatures and the	provided via air source neat						for item 22 below this table.
space heat and hot water)	pumps serving an ambient						Note that this is based on
c Manufacturer	temperature water loop at						one possible manufacturer
datasheets showing performance	between 15 and 25°C. The						for the equipment; no
under test conditions for the	air source heat pumps will be						procurement decisions have
specific source and sink	located within an external						been made yet, but the
temperatures of the proposed	roof plant compound, with						modelling methodology
development and assumptions for	pumps and central store in						would be similar for other
hours spent under changing	the ground floor heating plant						equivalent products. We
source temperatures. Whether	room. The system will						confirm that this
any additional technology is	provide a centralised energy						methodology has been
how this has been incorporated	loop to each apartment. In						followed.
into the energy modelling	each apartment, a water-					c)	As with b above, we have
assumptions.	water heat pump will produce					· · · ·	based the performance on
d. An estimate of the	heating or hot water as it						one manufacturer – and
expected heating costs to	extracts energy from the						details are included in the
occupants, demonstrating that the	central energy loop. The						supplementary information
costs have been minimised	apartment water heat pump						below this table – but no firm
through energy efficient design.	will provide space beating						decisions have been made
e. The expected heat	and hot water demand via						on the actual product to be
distribution system temperature	underfloor beating and an						installed An "equal or
with an explanation of how the	integrated bot water cylinder						approved" approach based
difference will be minimised to	integrated not water cylinder.						approved approach, Dased
ensure the system runs efficiently.	ASHD plant coloctions will						norformance engiliestics
f. A commitment to	ASHF plant selections will						performance specification,
monitor the performance of the	only be made once the						will be taken right through
	contractor has been						

heat pump system post- construction to ensure it is	appointed, but will be based		until final procurement by the
achieving the expected	efficiency (neak load and		d) As noted earlier Part I
performance approved during	seasonal) operating		annual energy consumption
planning. (It is recommended that	temperatures and acoustic		figures are - by virtue of the
borougns condition this).	criteria developed by the		fact they are used for
	design team at the next		
	stago		botwoon a proposed building
	Slage.		and a notional building
	We would be bappy to		boar little recomblance to the
	discuss further technical		
	details of the modelling at a		of buildings in use It is
	follow up mosting with the		therefore not appropriate to
	CLA should this he of		
	GLA, should this be of		use Part L ligures – such as
	benefit to getting agreement		those which have been
	to the proposed energy		obtained from the modelling
	strategy. with specific regard		undertaken as part of the
	to each point, we would		energy statement for
	comment that:		planning – to predict annual
	a. this information is		running costs. In addition, no
	not currently		decisions can yet be taken
	available		on the heating costs charged
	b. some guidance has		to future residents, as there
	been received from		are a number of unknown
	the heat pump		factors, including the future
	system		cost of electricity as well and
	manufacturer (		the extent to which the
	c. not currently		service and other charges
	available as the		payable by the residents
	final system is not		(who, under the S106 and
	confirmed.		purchasing requirements,
	d. Accurate heating		will all be signed up to some
	energy annual		form of care package) cover
	consumption		things such as central plant
	figures and		maintenance, communal
	associated energy		area energy consumption
	costs are nto		and incoming utility supplies.
	available. We would		We can, however, confirm

note that energy costs based on SAP / IES Part L modelling are not an accurate reflection of the actual energy use, due to the assumptions used for comparison		e) f)	that the direct energy costs payable per kwH to heat the apartments will be no greater than if the apartments were heated by a gas boiler or "traditional" equivalent. Agreed / confirmed agreed
purposes with the notional building			
However, the			
applicant is			
committed to			
keeping energy			
costs low and the			
energy strategy has			
been proposed with			
this in mind, so the			
bave been selected			
to be more efficient			
(and cost effective			
over its lifetime)			
than an equivalent			
"traditional" gas			
boiler system.			
e. As described			
elsewhere in this			
report, an efficient			
ambient			
temperature of 15-			
20 is proposed for			
the primary			
circulating loop, to			
minimise heat			
losses, promote			

	plant efficiency and provide flexibility in both heating and cooling modes. f. This would be welcomed.				
<b>PVs</b> 23. 90 kWp of PV is being proposed equating to circa 974 m2 of net PV area. A detailed roof layout has been provided demonstrating that the roof's potential for a PV installation has been maximised.	Agreed	-	Closed	-	Closed
<b>DOMESTIC CARBON SAVINGS</b> 24. An on-site reduction of 38.1 tonnes of CO2 per year in regulated emissions compared to a 2013 Building Regulations compliant development is expected for the domestic buildings, equivalent to an overall saving of 35%.	Agreed	-	Closed	-	Closed
25. The carbon dioxide savings meet the on-site target set within Policy 5.2 of the London Plan.	Agreed	-	Closed	-	Closed
NON-DOMESTIC CARBON SAVINGS 26. An on-site reduction of 32.6 tonnes of CO2 per year in regulated emissions compared to a 2013 Building Regulations compliant development is expected for the non-domestic buildings, equivalent to an overall saving of 35%.	Agreed	-	Closed	-	Closed
27. The carbon dioxide savings meet the target set within Policy 5.2 of the London Plan.	Agreed	-	Closed	-	Closed
28. All comments above should be addressed before compliance	Agreed	-	Closed	-	Closed

with London Plan energy policy			
can be verified.			

### Supporting Information

For item 5:

Figure 6.1 from the Energy Strategy

Table 6-1: Estimated Baseline, Be Lean, Be Clean and Be Green Regulated CO<sub>2</sub> Emissions

	Baseline (Tonnes CO <sub>2</sub> p.a.)	'Be Lean' (Tonnes CO <sub>2</sub> p.a.)	'Be Clean' (Tonnes CO <sub>2</sub> p.a.)	'Be Green' (Tonnes CO <sub>2</sub> p.a.)	Improvement over Baseline from 'Be Green' (%)
Domestic	108.9	106.6	106.6	70.8	35%
Non-domestic	93.2	87.9	87.9	60.6	35%
Site-wide Proposed Development	202.1	194.6	194.6	131.4	35%

### Domestic

				Base Line		Be Lean		Be Green	
URN	TFA (m2)	Sample Count	Average Sample Area (m2)	DER	Total CO2 in Tonnes represented by flat	DER	Total CO2 in Tonnes represented by flat	DER	Total CO2 in Tonnes represented by flat
02p02	104.6	12	89.8	14.1	15.2	13.2	14.3	9.2	9.9
02p05	97.2	7	92.2	14.2	9.2	13.6	8.8	9.4	6.0
02p09	88.3	16	84.6	13.8	18.7	13.2	17.8	8.8	11.9
02p12	94.5	17	92.7	13.2	20.8	12.8	20.2	8.6	13.5
02p15	82.8	9	84.2	13.6	10.3	14.1	10.7	9.4	7.1

02p19	53.1	20	69.0	15.7	21.6	14.8	20.4	8.9	12.2
04p01	98.8	2	75.7	15.9	2.4	16.4	2.5	11.3	1.7
04p10	123.5	1	129.6	13.9	1.8	14.2	1.8	10.0	1.3
05p03	103.2	3	107.5	16.9	5.5	19.0	6.1	13.3	4.3
05p08	121.2	2	121.8	14.1	3.4	16.5	4.0	11.6	2.8
					108.9		106.6		70.8
							2.1%		35%

### **Non-Domestic**

		Base Line		Be Lean		Be Green	
	TFA (m2)	BER	Total CO2 Tonnes	BER	Total CO2 Tonnes	BER	Total CO2 Tonnes
	3421.8	27.2	93.2	25.7	87.9	17.7	60.6
			93.2		87.9		60.6
					5.7%		35%
Total							
			202.1		194.6		131.4
					3.7%		35%

# For Item 6 and 13:

Extract from latest ground floor architect's drawing PA2.10 showing sunshades to restaurant terrace.

Memo Red & Yellow Specialist Extra Care - Melliss Avenue, Kew





10.5 So the improvements from energy efficiency alone can be understood, the appendix of the energy assessment must include a summary output sheet from the modelling work (i.e. a print out such as a full BRUKL report) only taking into account energy efficiency measures, **i.e. excluding CHP and renewable energy**. The 'be lean' case <u>should assume that the heating is provided by gas boilers and that any active cooling would be provided by electrically powered equipment</u>. The boilers should be assumed to have an efficiency of 89.5% for residential and 91% for non-residential and controls aligned with the Part L notional building assumptions. Higher efficiencies should only be used if gas boilers will be part of the final strategy (i.e. after the 'be clean' and 'be green' tiers of the hierarchy have also been addressed), in which case the gross efficiency of the gas boiler model to be specified can be used. If a communal heating system is being proposed, this should be included within the modelling for the 'be lean' case (i.e. the energy supply for a large apartment block would be provided by communal gas boilers not individual ones in each dwelling).

The London plan requirement for the "be lean" case (where in reality no boiler is to be used) is to use a value of 91%, not the value in the notional building, which could be much lower than this.

Heating fuel used in the Actual building	Space heating	Hot water	Heating fuel emission factor in the Notional building (kgCO <sub>2</sub> /kWh)	
Bio-fuels (i.e., whose emission factor < emission factor of natural gas)	63.0%	66.5%	The factor for the particular bio-fuel	
Natural gas			0.216	
LPG	04.00%	05.45%	0.241	
Dual fuel (Mineral + Wood)	81.9%	80.45%	0.226	
Fuel oil			0.319	
Electric heat pump	243.0%	256.5%	0.519	
Non-electric heat pump	126.0%	133.0%	The factor for the particular fuel	
Electricity (direct)				
Other fuels (i.e., whose emission factor > emission factor of fuel oil)	81.9%	86.45%	0.319	

It is not clear if this should be the seasonal, or system efficiency. As this does not impact the final target this is possibly of little importance. In this case, the SCOP has been input at 91%, with the Seasonal Efficiency a higher value of 96%. The SCOP is the value used in the calculations, with the Seasonal Efficiency reported on the BRUKL sheet.

Default?	System Name	Name:	FCU			
	FCU_1p5 CV	UK NCM type:	Fan coil s	ystems		UK NCM wizar
	CV_HP delMe	Heating Co	oling Hot v	vater Solar heating Aux energy Air su	Is proxy for Apac Is proxy for Apac	neHVAC system?*
~	FCU_FCU_1p5_HP FCU_HP	Generator:		Meter	Natural Gas: Meter 1	
	rads rads DHW			Seasonal efficiency		0.9580
	rads DHW HP rads_HP			Delivery efficiency		0.9499
				SCoP kW/kW		0.9100
		Heat recov	very:	Vent. heat recovery effectivene	ss	0.7500
				Vent. heat recovery return air t	emp °C	21.00
		CH(C)P:		Is this heat source used in conj	unction with CHP?	
				What ranking does this heat so	urce have after the CH(C)P plant?	1

### Item 8:

### Domestic

				Base Line		Be Lean		
URN	TFA (m2)	Sample Count	Average Sample Area (m2)	TFEE	Total Fabric Energy Efficiency (MWh/year)	DFEE	Total Fabric Energy Efficiency (MWh/year)	% improvement
02p02	104.6	12	89.8	39.1	42.1	35.8	38.6	8.4%
02p05	97.2	7	92.2	38.0	24.5	35.5	22.9	6.7%
02p09	88.3	16	84.6	33.3	45.1	32.0	43.4	3.9%
02p12	94.5	17	92.7	31.3	49.4	31.1	49.1	0.6%
02p15	82.8	9	84.2	30.8	23.4	34.2	25.9	-10.9%
02p19	53.1	20	69.0	28.7	39.7	27.5	38.0	4.2%
04p01	98.8	2	75.7	47.3	7.2	46.6	7.1	1.5%
04p10	123.5	1	129.6	42.7	5.5	42.4	5.5	0.7%
05p03	103.2	3	107.5	53.5	17.3	59.0	19.0	-10.3%
05p08	121.2	2	121.8	42.7	10.4	52.0	12.7	-21.7%

Total         264.6         Total         262.1         0.9%	Total	264.6	Total	262.1	0.9%	
--	-------	-------	-------	-------	------	--

# Item 13: Non domestic Overheating

The floor plan below shows uses for each space on the ground floor of the proposed development.



The extract below shows the system applied to each of these spaces. Only yellow and white areas are uncooled.



Unconditioned spaces are risers, plant rooms, and the cycle storage rooms. Heated only spaces are circulation spaces and changing rooms. All other spaces are cooled.

Initial IES results showing apparent minimal contribution from restaurant sunshades



# Amended results showing 3% improvement.

		With Sh	nade
	CO2	Cooling	Solar Gain
Actual (No Shade)	25.7	96.67	55.23
Actual (With Shade)	25.6	94.30	51.81
Notional	27.2	77.16	47.87
No Shade	5.5%	-25.3%	-15.4%
With Shade	5.9%	-22.2%	-8.2%

# For Item 15 and 19:

Ground floor indicative block plant layout showing primary heating plant and potential route for future district heating pipework.







## For Item 19:

This short text compares the proposed ambient loop air source system with a "traditional" high temperature heat pump system. It is in response to the GLA Response 2 to point 19:

• The system provides carbon savings beyond a traditional high temperature heat pump system in these circumstances.

Much of the data for this response is taken from the GLA Low Carbon Heat: Heat Pumps in London September 2018.

	- 114-104	
Ĵœ ₫	- 	
-0 <b>1</b>	<u>)</u> n }n	
	30m	and the second s
LOW C	ARBON HE	AT:
IEAT P	UMPSIN	LONDON

### Quoting from this report:

In order to deliver low carbon and affordable heat, the efficiency of heat pumps needs to be better understood by the building industry. The use of low temperature distribution systems and emitters, the method used to generate domestic hot water and the correct installation and commissioning of heat pump systems can all help to deliver low carbon emissions and operational energy costs. Heat pumps should not be seen as direct like-forlike replacements for gas-fired CHP. The proposed ambient loop system will benefit from improved COPs for a few reasons:

- Condenser temperatures are expected to be lower in the ambient loop system as
  - o there is no need to heat the water to such a high temperature
  - o return water temperatures are in practice higher than the cold water feed / radiator return temperatures available to the distributed systems.
- Losses from high temperature district heat networks are significant, and zero in the ambient loop system.

### Detail

Unpacking the points above requires consideration of how building wide district heating networks can actually work. It is useful to think of three classes:

- How these systems actually work in the real world, with all the errors and compromises made on site.
- The best these systems could theoretically perform, on paper.
- A fantasy system, that can't exist even in theory, but which would be very nice if it did.

This note will look at the gap between the second and third of these.

### **Return Temperatures**

To produce DHW at 65C, the lower limit PH engineers typically specify for regions of legionella control, the flow temperature has been set to 70C. For the majority of the year, the units will be in "keep hot" mode with a constant requirement for hot water at 65C, but an extremely low load on the HIU compared to the losses in the pipes. In these times the return temperature will be at 60C.

### **Standing Losses**

A model of the building was created in 3D, and assumed pipe lengths added for both flow and return. Following guidance in the heat network code of practice, multiple vertical risers have been used to reduce pipe lengths and thus losses:



Figure 3.8 – Benefits of using shared risers compared to horizontal runs for typical flat layouts

The image below shows the layout of the notional building wide heating network for the upper floors, using typical UK practice. Flow and return pipes start at a heat generator at ground floor level, and terminate at a HIU in each apartment.



# Measured pipe lengths are given in the table below:

		m
Flow	Single HIU Connection	470
Flow	Horizontal Distribution	261
Flow	Riser	114
Return	Single HIU Connection	267
Return	Horizontal Distribution	493
Return	Riser	109

Using insulation thicknesses from the district heating code of practice of

- 15mm for smaller pipes, and
- 20mm for thicker pipes,

and extremely high quality insulation with a conductivity of only 0.021 W/m/K gives a standing heat loss of 13kW.

Over the year this is 28% of the heat and DHW demand of the domestic areas. This is a much larger figure than the 5% assumed in SAP, the 10% figure used in the GLA heat pumps guide or the 15% "best practice" figure from the district heating code of practice. The 15% figure appears unachievable even in theory as doubling the thickness of insulation still results in a 20% loss.

The figures above are the theoretical maximum figures. They assume that the insulation is perfectly fitted everywhere, do not include losses from the HIU themselves, and assume the flow and return pipes hang happily in space, rather than being attached by hangers with the associated heat losses. The theoretical figure of 28% losses will be used from now on.

To see if this is typically achievable at the higher temperatures, we again turn to the GLA Heat Pumps in London document. Table 4.02 reproduced below shows typically air-water efficiencies of 3.84 are not achieved at the high temperature of 65°C.

The low temperature distribution system has been modelled with a COP of 3.0 based on manufactures data. To compensate for the minimum theoretical losses a higher temperature distribution system will need to have a COP of at least 3.0 \* (100%+28%) = 3.84.

		Efficiency at sp	ecific flow temp	erature (SCOP)		Typical
Heat pump type —	35 <sup>.</sup> C	45°C	55'C	60°C	65°C	efficiency
air-air	300%	1	U.	Ş	12	300%
air-water	340%	300%	250%	210%	170%	260%
ground-water	385%	365%	335%	305%	285%	320%

#### Table 4.02 - Heat pump efficiencies (SCOP) used in this study<sup>10</sup>

For these reasons, together with the associated overheating problems caused by high temperature systems, and that the building's occupants will be particularly sensitive to overheating, a low temperature loop is still the recommended option.

### For Item 22:

### b) Manufacturer's guidance on entering the ambient temperature heat pump system into Part L modelling software



#### Zeroth and putting the solution through SAP (2012)

Glen Dimplex Heating and Ventilation are currently undertaking in depth consultation with the Building Research Establishment (BRE) on how to correctly model the Zeroth Energy System within SAP. This document outlines two interim methods, which have been approved by the BRE, for use while the SAP methodology is suitably amended for SAP 10.

#### Overview

SAP is a calculation methodology used to prove compliance of a dwelling to Part L of the EnglandWales Building Regulations and Section 6 of the Scottish building Regulations. SAP is regulated by the BRE and both the software and assessors have to be accredited in order to perform the analysis. SAP analysis is typically conducted at two stages during the build cycle; as part of the planning submission and building completion. These stages are referred to as "design" and "as built". For the majority of projects, assessors are able to simply select a technology (for example an Air Source Heat Pump) and either input the efficiency or select the product from a database, where the products are listed by manufacturer (commonly referred to as Sa Appendix Q). Normally when designing a community heat network using technologies such as gas CHP and boilers, the assessor simply enters some details about the central plant and intended controls.

#### Net Read Provide Color & State

End Parket Second	Provident .		
	[bost	Connected water heat product database (h) 🔯 Scient prime how the database Inst leases	
	gan gank Ogerings	Type fail feelan Okomo institu finer	
Angeran Terrent Backariste in an angerant an angerant ang Angerant angerant ang	Therese Brokers Interfaction	And Anto Delay	there see
tguein Muddishur ale III Muddishur ale IIII Muddishur ale III Mudd	under merstend	Chier der Bullonize beter	
	fegruitin.	Nucleit Station gales	Pater Jose State
New Constant	Fagts	Caller 🔄	N Cent

#### Route 1: Zeroth with Heat Pumps

One of the most energy efficient ways to use Zeroth is with heat pumps as the central plant. The method provided by the BRE requires the assessor to either model the heat network with a default efficiency for heat pumps at 300% or if the ASHP SCOP is known (calculated to BSEN 14825) then this can be added to the box, as manufacturer declared. The value shown is for the Dimplex LA 60 TU or LA 60 TUR+ models. A distribution loss factor of 1.05 can be adopted for the network efficiency.

ingt. Rev Assesser (Office) - (Plan 1 Sec) (	eer vl	
and buildingFagulations Papots	rale	-
DV Indexed A Water I I Bell London, 131 WE		
NHER 🔬 🎬	🔊 🖬 🖇 🛷 🔺 🗐 🖉 🖻	
SPAC	FHEATING	
Office Options Spin	1-milita Milita V	
aling Campany of	ana Tanan yana da da da ana ana ana ana ana ana ana	
in Indones		O NHER
ter.	Paul Prodice Prices Health Rever	Record
n nge		6.05.09.0
res propu		
term Community or	AN AN DEC	0
Der Anital	Ababber ne 🖸	
pressing Debitsdowing	they Let	
e Creat	Changing optime tested to use, programmer and attest J rise & Terminitati	
fa Ballet	Children (1992)	(a) 100 D
		O Deel
		G Baar
		Mane
		<ul> <li>Boots</li> </ul>
		Ogeni
		_
desits Zewith Na deling 2013 on location et Linerage HLP-6 35 (704 55:25 Mar x	276/ws020000% C v C03308128023460000000 C v C0330812802346000000000 umme lang 10020 Umma 200 Umma	20% Ungen
e 🖬 💷	🔍 á 🌀 🌆 🔄 💶 🔕 🙆	<ul> <li>Vență</li> </ul>
		Space
NHER Plan Assesso	r 🔜	O Wager
	OURCE	O Research
ILAI -	OUNCE	O CENT
Efficiency source	Manufacturer de dared	· Result
Type	Heat pump	
Fuel	Electricity 🔤	
Fraction of heat	1	
	acil w	
thidency	204 79	
Heat to power ratio	0	

OK Cancel

#### General considerations

When modelling the Zeroth Energy System, it is important to remember that hot water services are provided using a cylinder. Therefore, the SAP assessor will need to enter the relevant values:

- Cylinder in dwelling
- Cylinder Volume 180L
- Heat loss from cylinder manufacturer declared
- Value 1.85 kwh/day



# c) Manufacturer's heat pump performance details (based on Glen Dimplex Zeroth Apartment Heat Pump with integrated cylinder)

Performance		ZHP4H-170	ZHP6H-170
Heating Capacity	kW	4	6
Required Capacity from Loop	kW	3.2	4.8
Coefficient of performance Heating	W25/W35	8.0	8.3
Coefficient of performance Heating	W25/W55	4.0	4.3
Nominal Flow Pate from Joon	m3/h	9.0	9.5
	***	0.55	D.OJ
Loop operating range	Raz	15-25 ON	a SK delta I
Minimum Heating flow rate	Ddl m3/h	0.7	1.02
Manimum Heating flow fale	m-/n	0.7	1.05
Sound nower level at 1m	dB(A)		33 43
Befrigerant	UD(A)	D410	45
Available Rump Head (Heat)	1ype/kg K410A/0.82		20 @ 1 02 m3/h
Available Pump Head (Loop)	kpa	53 @ 0.7 m²/h	39 @ 1.05 m <sup>2</sup> /h
Available Pullip Head (200p)	кра	55 @ 0.55 m-/n	55 @ 0.85 m/m
Dimensions and connections		550 v 5	50 2000
Dimensions	mm	550 x 5	50 x 2000
Filled weight	Kg	170 1	10/60 colit
Loop connections	Kg	1/8 OF 1	10/68 split
Loop connections	mm	22 00	oper stub
Drain Discharge (10mm clear base)	mm	1 Em longth	supplied loose
Discharge (C2 T and D Value)	mm	1.5m length	supplied loose
Cold Major inlet to cylinder	mm	22.00	10 mer stub
Hot Water outlet/return	mm	22 00	oper stub
ID rating		22 00	DVA
Expansion Vessel (heating)	Litre		8
Electrical	Entre		
Nominal Power Consumption Heat			
Pump, inc pumps (W25/W35)	kW	0.6	0.82
Electrical supply Immersion (230v)	A/Rating	9A with 10A	A Type B RCBO
Electrical supply HP Module (230v)	A/Rating	13A with 16	A Type C RCBO
Number of Electrical supplies			2
Hot water cylinder			
Туре		Unv	vented
Material		Stainle	ess Steel
Insulation		EPS	Foam
T&P Valve Rating		6 Bar	or 95°C
Maximum water inlet pressure	bar	6	
Capacity	L	180	
Integrated electric immersion	kW		2
Maximum temperature with immersion	°C	70	
Water regulations		G3 KIWA appr	oval to EN12897
T&P valve		Facto	ry fitted
Standing heat loss	kWh/24h	1	.85
Cylinder heat up time (from 10 to 60°C)	hrs	2.5	1.7
Accessories Supplied Loose		Tundish, preformed 1.5m hose, a	d discharge pipework, adjustable feet