



NOTES:

Cover Grades to BSEN124:
Trafficked areas - D400
Non-trafficked areas - C250
Pedestrian areas - B125

Gratings in pedestrian areas to be designed for pedestrian use (ie heel safe).

Average CBR 12.1% as per Mott McDonald GI Report April 2017

Any variations / soft spots to be reported to Engineer.

- When the surface course is not laid immediately after the Binder course the Binder course shall blinder & coated grit complying with BSEN13108 & BS 594987.
- The aggregate in surface course material shall have a min. PSV (Polished Stone Value) of 50 & a max. AAV (Aggregate Abrasion Value) of 14.
- Limestone aggregate or limestone filler shall not be permitted in Surface Course material or Binder Course material which is to be trafficked.
- Asphaltic Concrete shall comply & be laid in accordance with BS EN 13108 & BS 594987
- Design Life of all pavement options shall be 40 years HD24b(DMRB 7.2.1)
- Concrete Block Pavers shall comply with BS 6717:2000 & BS 7533-2:2002 Part 2

Drop Kerb Heights:
For Full Kerbs - 125mm
For Vehicle access - 25mm
For pedestrian access - 5mm

Refer to revision sheet for all amendment details

Rev	Date	General Revision	Drwn	chkd
A	30.07.19	Courts to be trafficked by emergency vehicles	JON	MC

issue for: **Draft CP**

This drawing is the copyright of Teicniuil Priory Consulting Engineers Ltd. No part of this drawing may be copied, transferred, or reproduced and is not for issue to third parties unless written consent is given by Teicniuil Priory Consulting Engineers Ltd.

Do Not Scale from drawing. Only written dimensions are to be taken in respect of this project.
All dimensions are in millimetres unless otherwise stated.
The designer is to be notified immediately of any suspect omissions or discrepancies.

This drawing is to be read in conjunction with all other relevant drawings and details.

Should there be any conflict between the details indicated on this drawing and those indicated on other drawings the Designer should be notified PRIOR to construction on site.

The Contractor is responsible for ensuring that all works are to the satisfaction of the Designer.

All workmanship is to be constructed in accordance with current Building Regulations.

All levels are in relation to Ordnance Datum, unless otherwise stated.

Client: Extraspace Solutions Ltd

Project Title: Collis Primary School

Drwg Title: Civil Details

Drwn by: JON	Date: July 19
chkd by: M.C	Date: July 19
Job No: 23-19	Scale: 1:20 / 1:10 / 1:5
Drwg No: 23-19-0-832	paper size: A1
Ref:	Sheet:
Rev:	Rev: A

ENGINEERING

SURVEYING

ARCHITECTURE

teicniuil-priory
consulting engineers

THE COURTYARD
FAIR HILL
KILLARNEY
CO. KERRY
TEL: 064 6631847
EMAIL: info@teicniuil.ie
WEB: www.teicniuil.ie