



Certificate of Compliance

Automatic Fire Suppression Systems:
Registered No: SQ1118A

It is hereby certified that the **Automatic Fire Sprinkler System** detailed below has been designed, installed, tested and commissioned in accordance with **BS 9251: 2014**

Deviations from that Standard, if any, have been formally agreed between Staysafe UK Ltd and the Local Authority having jurisdiction.

Address of Installation:
Flat E, Second Floor, 30 Broad Street, Teddington, Middx TW11 8RF

Installation Classification:	Domestic
Designed Water Flow and Pressure:	42 litres per min at 2.1 bar
Water Supply Pressure Recorded:	4 bar
Flow Rate Recorded at Manifold:	In excess of 110 litres per min
Sprinkler Head Manufacture and Type:	Tyco Series LF11 Residential RR
Date of Commissioning:	30 November 2018

Dated this day: 6 December 2018

Authorised by: 
Henry A Lloyd MRICS CbuilE MCABE MIAS



Staysafe (UK) Ltd
River House, High Street
Edenbridge, Kent, TN8 5AX
Tel: 0845 803 3228

