



# Certificate of Compliance

**Staysafe UK Ltd**

**Automatic Fire Suppression Systems:**

**Registered No: SQ1118A**

It is hereby certified that the **Automatic Fire Sprinkler System** detailed below has been designed, installed, tested and commissioned in accordance with **BS 9251: 2014**

*Deviations from that Standard, if any, have been formally agreed between Staysafe UK Ltd and the Local Authority having jurisdiction.*

**Address of Installation:**

**Flat F, Third Floor, 30 Broad Street, Teddington, Middx TW11 8RF**

<b>Installation Classification:</b>	<b>Domestic</b>
<b>Designed Water Flow and Pressure:</b>	<b>42 litres per min at 2.1 bar</b>
<b>Water Supply Pressure Recorded:</b>	<b>4 bar</b>
<b>Flow Rate Recorded at Manifold:</b>	<b>In excess of 110 litres per min</b>
<b>Sprinkler Head Manufacture and Type:</b>	<b>Tyco Series LF11 Residential RR</b>
<b>Date of Commissioning:</b>	<b>30 November 2018</b>

**Dated this day: 6 December 2018**

**Authorised by:** 

**Henry A Lloyd MRICS CbuilDE MCABE MIAS**



**Staysafe (UK) Ltd**  
**River House, High Street**  
**Edenbridge, Kent, TN8 5AX**  
**Tel: 0845 803 3228**

