

Aire House
12 Victoria Avenue
Harrogate, HG1 1ED



Date 17/08/2021 08:22
File 21495 SW.SRCX

Designed by AndyD
Checked by

Innovyze Source Control 2020.1.3

Summary of Results for 100 year Return Period (+40%)

Half Drain Time : 227 minutes.

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Control (l/s)	Max E Outflow (l/s)	Max Volume (m³)	Status
15 min Summer	98.439	0.439	0.0	2.3	2.3	33.3	O K
30 min Summer	98.554	0.554	0.0	2.3	2.3	42.1	O K
60 min Summer	98.647	0.647	0.0	2.3	2.3	49.2	O K
120 min Summer	98.698	0.698	0.0	2.3	2.3	53.0	O K
180 min Summer	98.694	0.694	0.0	2.3	2.3	52.7	O K
240 min Summer	98.676	0.676	0.0	2.3	2.3	51.3	O K
360 min Summer	98.638	0.638	0.0	2.3	2.3	48.5	O K
480 min Summer	98.602	0.602	0.0	2.3	2.3	45.8	O K
600 min Summer	98.567	0.567	0.0	2.3	2.3	43.1	O K
720 min Summer	98.531	0.531	0.0	2.3	2.3	40.3	O K
960 min Summer	98.453	0.453	0.0	2.3	2.3	34.4	O K
1440 min Summer	98.329	0.329	0.0	2.3	2.3	25.0	O K
2160 min Summer	98.205	0.205	0.0	2.3	2.3	15.6	O K
2880 min Summer	98.137	0.137	0.0	2.2	2.2	10.4	O K
4320 min Summer	98.087	0.087	0.0	1.8	1.8	6.6	O K
5760 min Summer	98.070	0.070	0.0	1.5	1.5	5.3	O K
7200 min Summer	98.060	0.060	0.0	1.2	1.2	4.6	O K
8640 min Summer	98.054	0.054	0.0	1.1	1.1	4.1	O K
10080 min Summer	98.050	0.050	0.0	1.0	1.0	3.8	O K
15 min Winter	98.494	0.494	0.0	2.3	2.3	37.5	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Discharge Volume (m³)	Time-Peak (mins)
15 min Summer	149.442	0.0	34.9	18
30 min Summer	96.326	0.0	45.0	33
60 min Summer	59.033	0.0	55.3	62
120 min Summer	34.948	0.0	65.5	122
180 min Summer	25.392	0.0	71.3	180
240 min Summer	20.134	0.0	75.4	206
360 min Summer	14.493	0.0	81.4	268
480 min Summer	11.475	0.0	86.0	336
600 min Summer	9.568	0.0	89.6	406
720 min Summer	8.244	0.0	92.6	476
960 min Summer	6.513	0.0	97.6	604
1440 min Summer	4.667	0.0	104.9	850
2160 min Summer	3.339	0.0	112.6	1188
2880 min Summer	2.631	0.0	118.3	1528
4320 min Summer	1.878	0.0	126.7	2204
5760 min Summer	1.478	0.0	133.0	2936
7200 min Summer	1.226	0.0	137.9	3672
8640 min Summer	1.053	0.0	142.1	4400
10080 min Summer	0.925	0.0	145.6	5112
15 min Winter	149.442	0.0	39.1	18

Aire House
12 Victoria Avenue
Harrogate, HG1 1ED



Date 17/08/2021 08:22
File 21495 SW.SRCX

Designed by AndyD
Checked by

Innovyze Source Control 2020.1.3

Summary of Results for 100 year Return Period (+40%)

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (1/s)	Max Control (1/s)	Max Σ Outflow (1/s)	Max Volume (m³)	Status
30 min Winter	98.624	0.624	0.0	2.3	2.3	47.4	O K
60 min Winter	98.732	0.732	0.0	2.3	2.3	55.6	O K
120 min Winter	98.797	0.797	0.0	2.3	2.3	60.6	O K
180 min Winter	98.800	0.800	0.0	2.3	2.3	60.8	O K
240 min Winter	98.780	0.780	0.0	2.3	2.3	59.3	O K
360 min Winter	98.732	0.732	0.0	2.3	2.3	55.6	O K
480 min Winter	98.685	0.685	0.0	2.3	2.3	52.0	O K
600 min Winter	98.636	0.636	0.0	2.3	2.3	48.3	O K
720 min Winter	98.586	0.586	0.0	2.3	2.3	44.5	O K
960 min Winter	98.473	0.473	0.0	2.3	2.3	35.9	O K
1440 min Winter	98.286	0.286	0.0	2.3	2.3	21.7	O K
2160 min Winter	98.138	0.138	0.0	2.2	2.2	10.5	O K
2880 min Winter	98.090	0.090	0.0	1.9	1.9	6.9	O K
4320 min Winter	98.065	0.065	0.0	1.4	1.4	5.0	O K
5760 min Winter	98.055	0.055	0.0	1.1	1.1	4.2	O K
7200 min Winter	98.049	0.049	0.0	0.9	0.9	3.7	O K
8640 min Winter	98.044	0.044	0.0	0.8	0.8	3.4	O K
10080 min Winter	98.041	0.041	0.0	0.7	0.7	3.1	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Discharge Volume (m³)	Time-Peak (mins)
30 min Winter	96.326	0.0	50.4	33
60 min Winter	59.033	0.0	61.9	62
120 min Winter	34.948	0.0	73.3	118
180 min Winter	25.392	0.0	79.9	174
240 min Winter	20.134	0.0	84.5	226
360 min Winter	14.493	0.0	91.2	282
480 min Winter	11.475	0.0	96.3	360
600 min Winter	9.568	0.0	100.4	438
720 min Winter	8.244	0.0	103.8	514
960 min Winter	6.513	0.0	109.3	656
1440 min Winter	4.667	0.0	117.5	892
2160 min Winter	3.339	0.0	126.2	1208
2880 min Winter	2.631	0.0	132.5	1500
4320 min Winter	1.878	0.0	141.9	2208
5760 min Winter	1.478	0.0	148.9	2944
7200 min Winter	1.226	0.0	154.5	3624
8640 min Winter	1.053	0.0	159.1	4408
10080 min Winter	0.925	0.0	163.1	5136

Aire House
 12 Victoria Avenue
 Harrogate, HG1 1ED



Date 17/08/2021 08:22
 File 21495 SW.SRCX

Designed by AndyD
 Checked by

Innovyze

Source Control 2020.1.3

Rainfall Details

Rainfall Model	FSR	Winter Storms	Yes
Return Period (years)	100	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	20.800	Shortest Storm (mins)	15
Ratio R	0.443	Longest Storm (mins)	10080
Summer Storms	Yes	Climate Change %	+40

Time Area Diagram

Total Area (ha) 0.125

Time (mins)		Area
From:	To:	(ha)
0	4	0.125

Model Details

Storage is Online Cover Level (m) 100.000

Cellular Storage Structure

Invert Level (m) 98.000 Safety Factor 2.0
 Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95
 Infiltration Coefficient Side (m/hr) 0.00000

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	80.0	0.0	0.801	0.0	0.0
0.800	80.0	0.0			

Hydro-Brake® Optimum Outflow Control

Unit Reference MD-SHE-0075-2300-0800-2300
 Design Head (m) 0.800
 Design Flow (l/s) 2.3
 Flush-Flo™ Calculated
 Objective Minimise upstream storage
 Application Surface
 Sump Available Yes
 Diameter (mm) 75
 Invert Level (m) 98.000
 Minimum Outlet Pipe Diameter (mm) 100
 Suggested Manhole Diameter (mm) 1200

Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	0.800	2.3
Flush-Flo™	0.238	2.3
Kick-Flo®	0.508	1.9
Mean Flow over Head Range	-	2.0

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	2.0	1.200	2.8	3.000	4.2	7.000	6.3
0.200	2.3	1.400	3.0	3.500	4.5	7.500	6.5
0.300	2.3	1.600	3.2	4.000	4.8	8.000	6.7
0.400	2.2	1.800	3.3	4.500	5.1	8.500	6.9
0.500	1.9	2.000	3.5	5.000	5.4	9.000	7.1
0.600	2.0	2.200	3.7	5.500	5.6	9.500	7.3
0.800	2.3	2.400	3.8	6.000	5.9		
1.000	2.5	2.600	4.0	6.500	6.1		