

Aire House  
12 Victoria Avenue  
Harrogate, HG1 1ED



Date 25/02/2022 17:27  
File 21495 SW.SRCX

Designed by Rob  
Checked by

Innovyze Source Control 2020.1

Summary of Results for 100 year Return Period (+40%)

Half Drain Time : 256 minutes.

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Control (l/s)	Max E Outflow (l/s)	Max Volume (m³)	Status
15 min Summer	98.414	0.414	0.0	2.1	2.1	33.5	O K
30 min Summer	98.525	0.525	0.0	2.1	2.1	42.4	O K
60 min Summer	98.617	0.617	0.0	2.1	2.1	49.8	O K
120 min Summer	98.672	0.672	0.0	2.1	2.1	54.2	O K
180 min Summer	98.675	0.675	0.0	2.1	2.1	54.5	O K
240 min Summer	98.659	0.659	0.0	2.1	2.1	53.2	O K
360 min Summer	98.627	0.627	0.0	2.1	2.1	50.6	O K
480 min Summer	98.595	0.595	0.0	2.1	2.1	48.0	O K
600 min Summer	98.563	0.563	0.0	2.1	2.1	45.5	O K
720 min Summer	98.532	0.532	0.0	2.1	2.1	42.9	O K
960 min Summer	98.463	0.463	0.0	2.1	2.1	37.4	O K
1440 min Summer	98.350	0.350	0.0	2.1	2.1	28.2	O K
2160 min Summer	98.229	0.229	0.0	2.1	2.1	18.5	O K
2880 min Summer	98.156	0.156	0.0	2.0	2.0	12.6	O K
4320 min Summer	98.093	0.093	0.0	1.8	1.8	7.5	O K
5760 min Summer	98.074	0.074	0.0	1.5	1.5	6.0	O K
7200 min Summer	98.063	0.063	0.0	1.2	1.2	5.1	O K
8640 min Summer	98.056	0.056	0.0	1.1	1.1	4.5	O K
10080 min Summer	98.051	0.051	0.0	0.9	0.9	4.2	O K
15 min Winter	98.466	0.466	0.0	2.1	2.1	37.7	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Discharge Volume (m³)	Time-Peak (mins)
15 min Summer	149.442	0.0	34.8	18
30 min Summer	96.326	0.0	45.0	33
60 min Summer	59.033	0.0	55.3	62
120 min Summer	34.948	0.0	65.4	122
180 min Summer	25.392	0.0	71.3	180
240 min Summer	20.134	0.0	75.4	220
360 min Summer	14.493	0.0	81.4	280
480 min Summer	11.475	0.0	86.0	344
600 min Summer	9.568	0.0	89.6	414
720 min Summer	8.244	0.0	92.6	484
960 min Summer	6.513	0.0	97.6	610
1440 min Summer	4.667	0.0	104.9	864
2160 min Summer	3.339	0.0	112.6	1212
2880 min Summer	2.631	0.0	118.3	1556
4320 min Summer	1.878	0.0	126.6	2208
5760 min Summer	1.478	0.0	133.0	2936
7200 min Summer	1.226	0.0	137.9	3672
8640 min Summer	1.053	0.0	142.0	4400
10080 min Summer	0.925	0.0	145.6	5136
15 min Winter	149.442	0.0	39.0	18

Aire House  
12 Victoria Avenue  
Harrogate, HG1 1ED



Date 25/02/2022 17:27  
File 21495 SW.SRCX

Designed by Rob  
Checked by

Innovyze Source Control 2020.1

Summary of Results for 100 year Return Period (+40%)

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Control (l/s)	Max Σ Outflow (l/s)	Max Volume (m³)	Status
30 min Winter	98.591	0.591	0.0	2.1	2.1	47.7	O K
60 min Winter	98.697	0.697	0.0	2.1	2.1	56.3	O K
120 min Winter	98.765	0.765	0.0	2.1	2.1	61.8	O K
180 min Winter	98.775	0.775	0.0	2.1	2.1	62.6	O K
240 min Winter	98.762	0.762	0.0	2.1	2.1	61.5	O K
360 min Winter	98.719	0.719	0.0	2.1	2.1	58.1	O K
480 min Winter	98.680	0.680	0.0	2.1	2.1	54.9	O K
600 min Winter	98.638	0.638	0.0	2.1	2.1	51.5	O K
720 min Winter	98.594	0.594	0.0	2.1	2.1	48.0	O K
960 min Winter	98.499	0.499	0.0	2.1	2.1	40.3	O K
1440 min Winter	98.323	0.323	0.0	2.1	2.1	26.1	O K
2160 min Winter	98.167	0.167	0.0	2.1	2.1	13.5	O K
2880 min Winter	98.099	0.099	0.0	1.9	1.9	8.0	O K
4320 min Winter	98.069	0.069	0.0	1.4	1.4	5.6	O K
5760 min Winter	98.057	0.057	0.0	1.1	1.1	4.6	O K
7200 min Winter	98.050	0.050	0.0	0.9	0.9	4.0	O K
8640 min Winter	98.045	0.045	0.0	0.8	0.8	3.7	O K
10080 min Winter	98.042	0.042	0.0	0.7	0.7	3.4	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Discharge Volume (m³)	Time-Peak (mins)
30 min Winter	96.326	0.0	50.4	33
60 min Winter	59.033	0.0	61.9	62
120 min Winter	34.948	0.0	73.3	118
180 min Winter	25.392	0.0	79.9	176
240 min Winter	20.134	0.0	84.5	230
360 min Winter	14.493	0.0	91.2	292
480 min Winter	11.475	0.0	96.3	368
600 min Winter	9.568	0.0	100.3	446
720 min Winter	8.244	0.0	103.8	522
960 min Winter	6.513	0.0	109.3	674
1440 min Winter	4.667	0.0	117.5	910
2160 min Winter	3.339	0.0	126.2	1232
2880 min Winter	2.631	0.0	132.5	1528
4320 min Winter	1.878	0.0	141.9	2208
5760 min Winter	1.478	0.0	148.9	2936
7200 min Winter	1.226	0.0	154.5	3648
8640 min Winter	1.053	0.0	159.1	4408
10080 min Winter	0.925	0.0	163.1	5112

Aire House  
 12 Victoria Avenue  
 Harrogate, HG1 1ED



Date 25/02/2022 17:27  
 File 21495 SW.SRCX

Designed by Rob  
 Checked by

Innovyze Source Control 2020.1


Rainfall Details

Rainfall Model	FSR	Winter Storms	Yes
Return Period (years)	100	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	20.800	Shortest Storm (mins)	15
Ratio R	0.443	Longest Storm (mins)	10080
Summer Storms	Yes	Climate Change %	+40

Time Area Diagram

Total Area (ha) 0.125

Time (mins)	Area
From:	To: (ha)
0	4 0.125

Topping Engineers Ltd		Page 4
Aire House 12 Victoria Avenue Harrogate, HG1 1ED		
Date 25/02/2022 17:27	Designed by Rob	
File 21495 SW.SRCX	Checked by	
Innovyze	Source Control 2020.1	

Model Details

Storage is Online Cover Level (m) 100.000

Cellular Storage Structure

Invert Level (m) 98.000 Safety Factor 2.0  
 Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95  
 Infiltration Coefficient Side (m/hr) 0.00000

Depth (m)	Area (m <sup>2</sup> )	Inf. Area (m <sup>2</sup> )	Depth (m)	Area (m <sup>2</sup> )	Inf. Area (m <sup>2</sup> )
0.000	85.0	85.0	0.900	0.0	114.6
0.800	85.0	114.6			

Hydro-Brake® Optimum Outflow Control

Unit Reference MD-SHE-0072-2100-0800-2100  
 Design Head (m) 0.800  
 Design Flow (l/s) 2.1  
 Flush-Flo™ Calculated  
 Objective Minimise upstream storage  
 Application Surface  
 Sump Available Yes  
 Diameter (mm) 72  
 Invert Level (m) 98.000  
 Minimum Outlet Pipe Diameter (mm) 100  
 Suggested Manhole Diameter (mm) 1200

Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	0.800	2.1
Flush-Flo™	0.241	2.1
Kick-Flo®	0.510	1.7
Mean Flow over Head Range	-	1.8

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	1.9	1.200	2.5	3.000	3.9	7.000	5.7
0.200	2.1	1.400	2.7	3.500	4.1	7.500	5.9
0.300	2.1	1.600	2.9	4.000	4.4	8.000	6.1
0.400	2.0	1.800	3.0	4.500	4.7	8.500	6.3
0.500	1.8	2.000	3.2	5.000	4.9	9.000	6.5
0.600	1.8	2.200	3.3	5.500	5.1	9.500	6.6
0.800	2.1	2.400	3.5	6.000	5.3		
1.000	2.3	2.600	3.6	6.500	5.5		