

STANDARD NOTES

SCHEDULES.

- I. DO NOT SCALE FROM THIS DRAWING. CONFIRM ALL DIMENSIONS AND STRUCTURAL INFORMATION ON SITE, IF IN DOUBT ASK BEFORE ACTING.
- . THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE APPROPRIATE WB|SHIELS REPORT AND

- THE ELECTRICAL INSTALLATION SHALL COMPLY WITH BS7671:2018 18TH EDITION.
- THE ARCHITECTURAL BACKGROUND SHOWN IS ONLY FOR REFERENCE. THE CONTRACTOR SHALL REFER TO THE ARCHITECTS PACKAGE FOR FULL AND FINAL DESIGN OF ALL ARCHITECTURAL ELEMENTS.

13A TWIN SWITCHED SOCKET OUTLET

13A TWIN UNSWITCHED SOCKET OUTLET

13A TWIN SWITCHED SOCKET OUTLET WITH USB

13A SWITCHED SINGLE SOCKET OUTLET

-'C' DENOTES CLEANERS SOCKET

13A SWITCHED FUSED CONNECTION UNIT

110V SOCKET OUTLET C/W ISOLATING

13A UNSWITCHED FUSED CONNECTION UNIT

BS EN 60309 SOCKET OUTLET -'n' DENOTES RATED VOLTAGE

TRANSFORMER 13A SWITCHED FUSED CONNECTION UNIT TO

UNSWITCHED SINGLE SOCKET OUTLET

13A SWITCHED FUSED CONNECTION UNIT TO FLEX OUTLET BELOW

1 COMPARTMENT FLOORBOX (REFER TO FLOORBOX SCHEDULE FOR FURTHER DETAILS)

2 COMPARTMENT FLOORBOX (REFER TO FLOORBOX SCHEDULE FOR FURTHER DETAILS)

3 COMPARTMENT FLOORBOX (REFER TO

FLOORBOX SCHEDULE FOR FURTHER

4 COMPARTMENT FLOORBOX (REFER TO FLOORBOX SCHEDULE FOR FURTHER

5 COMPARTMENT FLOORBOX (REFER TO FLOORBOX SCHEDULE FOR FÜRTHER

DETAILS)

DETAILS)

DETAILS)

2 POLE IP67 ROTARY ISOLATOR

-'n' DENOTES RATING OF ISOLATOR

4 POLE IP67 ROTARY ISOLATOR -'n' DENOTES RATING OF ISOLATOR POWER SUPPLY UNIT

EMERGENCY PUSH BUTTON

ELECTRICAL METER

ELECTRICAL TRANSFORMER

CAT6 RJ45 DATA OUTLET

EARTH CONECTION

-'n' DENOTES QUAINTLY OF OUTLETS MCB DISTRIBUTION BOARD

MCCB SWITCHPANEL

BMS PANEL

BRUSH PLATE

SMART BOARD

KITCHEN PLATE

HAND DRYER HAIR DRYER COFFEE MACHINE

DISHWASHER MW: MICROWAVE ZIP TAP

WATER DISPENSER PRINTER SATELLITE CABINET

DM: DESKTOP MODULES (EACH CONNECT TO 4 SOCKET OUTLETS ON

THE DESK) RS: RETRACTABLE SCREEN PJ: PROJECTOR

 P1
 05/09/22
 WC
 DRAFT FOR PLANNING

 REV
 DATE
 BY
 DESCRIPTION
DRAFT FOR PLANNING FOR PLANNING

10 CHANCEL STREET, LONDON, SE1 0UX TEL: +44 (0)203 764 0801 WWW.WBSHIELS.COM

09498732. Registered Office: 20-22 Wenlock Road, London, N1 GU.

KNELLER HALL FOR PLANNING

MAIN BUILDING ELECTRICAL SMALL POWR & DATA LAYOUT - GROUND FLOOR

1:100@ A0

DRAWING No. | P2389_62_L0_10