




CALCULATIONS

Company: WIE Office: London
 Sheet No: 1 of 1 Project No: WIE10667
 By: N Balboni Date: 27.09.2017
 Checked: D O'Donovan Date: 27.09.2017

Project Title: **Former Stag Brewery, Mortlake**
 Calculations Title: **Tide Locking Calculation**

CALCULATIONS						
The 'rule of twelfths' is a rule of thumb that allows the tide level to be estimated based on the high and low water levels. The rule is an approximation assuming six hours between high and low water, and does not take account of geographical location.						
Source: Port of London Authority, 2017. <i>Tide Tables and Port Information</i>						
Closest tidal stations: Barnes and Chiswick.						
Barnes MHWS (m AOD)	4.13					
Chiswick MHWS (m AOD)	4.08					
Inputs			Rule of Twelfths			
Mean High Water Spring	=	5.23 m AOD	Hour	Change	Water Level	
Mean Low Water Spring	=	-1.02 m AOD	0	-	-1.02	
			1	1/12	-0.50	
Invert Level of Outfall	=	2.60 m AOD	2	1/6	0.54	
			3	1/4	2.11	
			4	1/4	3.67	
			5	1/6	4.71	
			6	1/12	5.23	
			7	1/12	4.71	
			8	1/6	3.67	
			9	1/4	2.11	
			10	1/4	0.54	
			11	1/6	-0.50	
			12	1/12	-1.02	
Output						
Time that outfall becomes submerged (hrs)	=		3.3			
Time that outfall becomes unsubmerged (hrs)	=		8.6			
Total time that outfall is submerged (hrs)	=		5.3			

Waterman Infrastructure & Environment		Page 1
Pickfords Wharf Clink Street London SE1 9DG		
Date 29/09/2017 11:44 File 170926 CULVERT CHECK.MDX	Designed by CSNB2 Checked by	
Micro Drainage	Network 2017.1.2	

STORM SEWER DESIGN by the Modified Rational Method

Design Criteria for Storm





Pipe Sizes STANDARD Manhole Sizes STANDARD

FEH Rainfall Model

Return Period (years)	100
FEH Rainfall Version	1999
Site Location GB 520450 176000 TQ 20450 76000	
C (1km)	-0.024
D1 (1km)	0.322
D2 (1km)	0.262
D3 (1km)	0.219
E (1km)	0.306
F (1km)	2.539
Maximum Rainfall (mm/hr)	0
Maximum Time of Concentration (mins)	5
Foul Sewage (l/s/ha)	0.000
Volumetric Runoff Coeff.	0.750
PIMP (%)	100
Add Flow / Climate Change (%)	40
Minimum Backdrop Height (m)	0.200
Maximum Backdrop Height (m)	1.500
Min Design Depth for Optimisation (m)	1.200
Min Vel for Auto Design only (m/s)	1.00
Min Slope for Optimisation (1:X)	500

Designed with Level Soffits

Network Design Table for Storm

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
1.000	124.000	0.012	10333.3	0.300	5.00	0.0	0.600	[]	-1	Pipe/Conduit	
1.001	2.949	0.590	5.0	0.000	0.00	0.0	0.600	o	675	Pipe/Conduit	
1.002	7.594	0.051	150.0	0.000	0.00	0.0	0.600	o	675	Pipe/Conduit	
1.003	25.890	1.295	20.0	0.000	0.00	0.0	0.600	o	675	Pipe/Conduit	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
1.000	0.00	5.00	5.480	0.300	0.0	0.0	0.0	0.14	67.5	0.0
1.001	0.00	5.00	4.945	0.300	0.0	0.0	0.0	11.77	4211.0	0.0
1.002	0.00	5.00	4.355	0.300	0.0	0.0	0.0	2.14	765.0	0.0
1.003	0.00	5.00	4.305	0.300	0.0	0.0	0.0	5.88	2103.1	0.0

PIPELINE SCHEDULES for Storm

Upstream Manhole

PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
1.000	[]	-1	1	6.030	5.480	0.400	Open Manhole	3000
1.001	o	675	2	6.030	4.945	0.410	Open Manhole	3000
1.002	o	675	3	6.030	4.355	1.000	Open Manhole	1500
1.003	o	675	3	6.030	4.305	1.050	Open Manhole	2100

Downstream Manhole

PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
1.000	124.000	10333.3	2	6.030	5.468	0.412	Open Manhole	3000
1.001	2.949	5.0	3	6.030	4.355	1.000	Open Manhole	1500
1.002	7.594	150.0	3	6.030	4.305	1.050	Open Manhole	2100
1.003	25.890	20.0		4.500	3.010	0.815	Open Manhole	675

Surcharged Outfall Details for Storm

Outfall Pipe Number	Outfall Name	C. Level (m)	I. Level (m)	Min I. Level (m)	D,L (mm)	W (mm)
1.003		4.500	3.010	2.625	675	0

Datum (m) 0.000 Offset (mins) 0

Time (mins)	Depth (m)	Time (mins)	Depth (m)	Time (mins)	Depth (m)	Time (mins)	Depth (m)	Time (mins)	Depth (m)	Time (mins)	Depth (m)
30	5.230	90	5.230	150	5.230	210	5.230	270	5.230	330	5.230
60	5.230	120	5.230	180	5.230	240	5.230	300	5.230	360	5.230

Simulation Criteria for Storm

Volumetric Runoff Coeff 0.750 Additional Flow - % of Total Flow 0.000
Areal Reduction Factor 1.000 MADD Factor * 10m³/ha Storage 2.000
Hot Start (mins) 0 Inlet Coefficient 0.800
Hot Start Level (mm) 0 Flow per Person per Day (l/per/day) 0.000
Manhole Headloss Coeff (Global) 0.500 Run Time (mins) 60
Foul Sewage per hectare (l/s) 0.000 Output Interval (mins) 1

Number of Input Hydrographs 0 Number of Storage Structures 0
Number of Online Controls 0 Number of Time/Area Diagrams 0
Number of Offline Controls 0 Number of Real Time Controls 0

Synthetic Rainfall Details

Pickfords Wharf
Clink Street
London SE1 9DG



Date 29/09/2017 11:44
File 170926 CULVERT CHECK.MDX

Designed by CSNB2
Checked by

Micro Drainage Network 2017.1.2

Synthetic Rainfall Details

Rainfall Model	FEH
Return Period (years)	100
FEH Rainfall Version	1999
Site Location	GB 520450 176000 TQ 20450 76000
C (1km)	-0.024
D1 (1km)	0.322
D2 (1km)	0.262
D3 (1km)	0.219
E (1km)	0.306
F (1km)	2.539
Summer Storms	Yes
Winter Storms	No
Cv (Summer)	0.750
Cv (Winter)	0.840
Storm Duration (mins)	30

Summary of Critical Results by Maximum Level (Rank 1) for Storm

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m ³ /ha Storage	2.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs	0	Number of Storage Structures	0
Number of Online Controls	0	Number of Time/Area Diagrams	0
Number of Offline Controls	0	Number of Real Time Controls	0

Synthetic Rainfall Details


Rainfall Model	FEH
FEH Rainfall Version	1999
Site Location	GB 520450 176000 TQ 20450 76000
C (1km)	-0.024
D1 (1km)	0.322
D2 (1km)	0.262
D3 (1km)	0.219
E (1km)	0.306
F (1km)	2.539
Cv (Summer)	0.750
Cv (Winter)	0.840

Margin for Flood Risk Warning (mm)	300.0	DVD Status	OFF
Analysis Timestep	Fine	Inertia Status	OFF
DTS Status	ON		

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	100
Climate Change (%)	40

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surge	First (Y) Flood	First (Z) Overflow	Overflow Act.	Water Level (m)
1.000	1	15 Winter	100	+40%	100/15	Summer			5.824
1.001	2	60 Summer	100	+40%					5.274
1.002	3	60 Summer	100	+40%	100/30	Summer			5.267
1.003	3	60 Summer	100	+40%	100/30	Summer			5.254

PN	US/MH Name	Surcharged		Flooded		Pipe		Level Exceeded
		Depth (m)	Volume (m ³)	Flow / Cap. (l/s)	Overflow (l/s)	Flow (l/s)	Status	
1.000	1	0.194	0.000	1.29	285.9	FLOOD RISK		
1.001	2	-0.346	0.000	0.15	147.8	OK		
1.002	3	0.237	0.000	0.35	148.7	SURCHARGED		

Waterman Infrastructure & Environment		Page 5
Pickfords Wharf Clink Street London SE1 9DG		
Date 29/09/2017 11:44 File 170926 CULVERT CHECK.MDX	Designed by CSNB2 Checked by	
Micro Drainage		Network 2017.1.2

Summary of Critical Results by Maximum Level (Rank 1) for Storm

PN	US/MH Name	Surcharged		Flooded		Pipe		Level Exceeded
		Depth (m)	Volume (m ³)	Flow / Cap.	Overflow (l/s)	Flow (l/s)	Status	
1.003	3	0.274	0.000	0.10		149.6	SURCHARGED	

CHART DATUMS & STANDARD LEVELS IN THE PORT OF LONDON

1. **Chart Datum** is set to approximately the level of Lowest Astronomical Tide (L.A.T.)
2. **Low Water levels** in the upper reaches of the tidal Thames are greatly affected by the land water flow at Teddington Weir. **They frequently fall below chart datum** when this flow is significantly reduced, typically during the summer months.
3. **Maintained level** and chart datum above Richmond half tide weir are both 1.72 metres above Ordnance Datum (Newlyn).
4. **Trinity High Water (T.H.W.)** is deemed, by the Port of London Act, 1968, to be a level having a value of 11.4 feet (**i.e. 3.475 metres**) above Ordnance Datum (Newlyn).

Tidal Station	Level of Chart Datum below Ordnance Datum (Newlyn) m	Standard levels above local C.D.				
		Mean Low Water Springs MLWS	Mean Low Water Neaps MLWN	Mean High Water Neaps MHWN	Mean High Water Springs MHWS	Highest Astronomical Tide (HAT)
WALTON	2.16	0.5	1.1	3.5	4.3	4.7
MARGATE	2.50	0.6	1.3	4.0	4.8	5.1
SHIVERING SAND	-	0.6	1.4	4.4	5.4	5.7
SOUTHEND	2.90	0.6	1.4	4.8	5.9	6.3
CANVEY	2.97	0.6	1.4	5.0	6.1	6.6
CORYTON	3.05	0.6	1.5	5.1	6.2	6.7
TILBURY	3.12	0.6	1.5	5.4	6.6	7.0
GREENHITHE	3.20	0.6	1.6	5.6	6.7	7.2
DAGENHAM	3.28	0.6	1.6	5.8	7.0	7.5
NORTH WOOLWICH	3.35	0.6	1.6	5.9	7.2	7.7
TOWER	3.20	0.5	1.5	5.9	7.1	7.6
BLACKFRIARS	3.05	0.5	1.4	5.8	7.0	7.5
WESTMINSTER	2.90	0.5	1.3	5.7	6.9	7.4
VAUXHALL	2.59	0.3	1.0	5.4	6.6	7.1
VICTORIA RAIL	2.44	0.3	0.9	5.3	6.5	6.9
ALBERT BRIDGE	2.29	0.3	0.9	5.1	6.3	6.8
WANDSWORTH	2.13	0.3	0.9	5.0	6.2	6.7
PUTNEY	1.98	0.3	0.8	4.9	6.1	6.6
HAMMERSMITH	1.68	0.3	0.7	4.7	5.8	6.4
BARNES	1.37	0.2	0.6	4.4	5.5	6.1
CHISWICK	1.22	0.2	0.5	4.3	5.3	6.0
KEW	1.07	0.2	0.5	4.2	5.2	5.9
BRENTFORD	0.91	0.1	0.4	4.0	5.0	5.7
RICHMOND	0.61	0.1	0.2	3.8	4.8	5.5
TWICKENHAM	Note 3	-		1.5	2.5	3.2