

# Water Efficiency Calculator for New Dwellings



## Project Details

Address/Reference	Plot 1_Hunters Lodge	Case Reference	230607
Number of Bedrooms	2	Occupancy for Calculation Purposes	3

## Appliance/Usage Details

### Taps (Excluding Kitchen Taps)

Tap Fitting Type	Flow Rate Litres/Min	Quantity (No.)	Total per Fitting type
V&B	5.00	3	15.00
			0.00
			0.00
			0.00
			0.00
			0.00
<b>Total No. of Fittings (No.)</b>		<b>3</b>	
<b>Total Flow (l/s)</b>			<b>15.00</b>
<b>Maximum Flow (l/s)</b>			<b>5.00</b>
<b>Average Flow (l/s)</b>			<b>5.00</b>
<b>Weighted Average Flow (l/s)</b>			<b>3.50</b>
<b>Flow for Calculation (l/s)</b>			<b>5.00</b>

### Showers

Shower fitting Type	Flow Rate Litres/Min	Quantity (No.)	Total per Fitting type
V&B Free unit	9.00	1	9.00
V&B Over Bath	9.00	1	9.00
V&B Hand Shower	6.00	1	6.00
			0.00
			0.00
			0.00
<b>Total No. of Fittings (No.)</b>		<b>3</b>	
<b>Total Flow (l/s)</b>			<b>24.00</b>
<b>Maximum Flow (l/s)</b>			<b>9.00</b>
<b>Average Flow (l/s)</b>			<b>8.00</b>
<b>Weighted Average Flow (l/s)</b>			<b>6.30</b>
<b>Flow for Calculation (l/s)</b>			<b>8.00</b>

### Baths

Bath Type	Capacity to Overflow	Quantity (No.)	Total per Fitting type
V&B Signature	190.00	1	190.00
			0.00
			0.00
			0.00
<b>Total No. of Fittings (No.)</b>		<b>1</b>	
<b>Total Capacity (l)</b>			<b>190.00</b>
<b>Maximum Capacity (l)</b>			<b>190.00</b>
<b>Average Capacity (l)</b>			<b>190.00</b>
<b>Weighted Average Capacity (l)</b>			<b>133.00</b>
<b>Capacity for Calculation (l)</b>			<b>190.00</b>

### WCs

WC Type	Full Flush Volume	Part Flush Volume	Quantity (No.)
V&B WC	6.00	4.00	3
<b>Total number of fittings</b>			<b>3</b>
<b>Average effective flushing volume</b>			<b>4.67</b>

### Dishwashers

Dishwasher Type	L per Place Setting	Quantity (No.)	Total per Fitting type
Siemens	0.90	1	0.90
			0.00
<b>Total No. of Fittings (No.)</b>		<b>1</b>	
<b>Total Consumption (l)</b>			<b>0.90</b>
<b>Maximum Consumption (l)</b>			<b>0.90</b>
<b>Average Consumption (l/s)</b>			<b>0.90</b>
<b>Weighted Average Consumption (l)</b>			<b>0.63</b>
<b>Consumption for Calculation (l/s)</b>			<b>0.90</b>

### Washing Machines

Washing Machine Type	L per Kg Dry Load	Quantity (No.)	Total per Fitting type
Siemens	6.00	1	6.00
			0.00
<b>Total No. of Fittings (No.)</b>		<b>1</b>	
<b>Total Consumption (l)</b>			<b>6.00</b>
<b>Maximum Consumption (l)</b>			<b>6.00</b>
<b>Average Consumption (l/s)</b>			<b>6.00</b>
<b>Weighted Average Consumption (l)</b>			<b>4.20</b>
<b>Consumption for Calculation (l/s)</b>			<b>6.00</b>

### Kitchen Taps

Tap Fitting Type	Flow Rate Litres/Min	Quantity (No.)	Total per Fitting type
V&B KTC	6.00	1	6.00
			0.00
			0.00
<b>Total No. of Fittings (No.)</b>		<b>1</b>	
<b>Total Flow (l/s)</b>			<b>6.00</b>
<b>Maximum Flow (l/s)</b>			<b>6.00</b>
<b>Average Flow (l/s)</b>			<b>6.00</b>
<b>Weighted Average Flow (l/s)</b>			<b>4.20</b>
<b>Flow for Calculation (l/s)</b>			<b>6.00</b>

### Other Fittings

Waste Disposal Y/N	
Water softner	
Consumption beyond 4% l/p/d	

### Use of grey water and harvested rainwater

<b>Total Grey water from WHB taps (l)</b>	
<b>Total Available Grey Water Supply (l)</b>	167.58
<b>Possible Demand (l)</b>	99.68
<b>Grey/Rain Installed Capacity (l)</b>	
<b>Figure for Calculation lit/person/day</b>	0.00

## Water Use Assessment

Installation Type	Unit	Capacity/ Flow Rate	Use Factor	Fixed use (l/p/day)	Total Use (l/p/day)
WC Single Flush	Volume (l)	0.00	4.42	0.00	0.00
WC Dual Flush	Full Flush (l)	0.00	1.46	0.00	0.00
	Pt Flush (l)	0.00	2.96	0.00	0.00
WC's (Multiple)	Volume (l)	4.67	4.42	0.00	20.63
Taps Exc. Kitchen	Flow Rate (l/s)	5.00	1.58	1.58	9.48
Bath (shower present)	(l/s)	190.00	0.11	0.00	20.90
Shower (bath present)	(l/s)	8.00	4.37	0.00	34.96
Bath Only	(l)	0.00	0.50	0.00	0.00
Shower Only	(l/s)	0.00	5.60	0.00	0.00
Kitchen Taps	(l/s)	6.00	0.44	10.36	13.00
Washing Machines	(l/kgdry)	6.00	2.10	0.00	12.60
Dishwashers	(l/place)	0.90	3.60	0.00	3.24
Waste Disposal	(l/s)	0.00	3.08	0.00	0.00
Water Softner	(l/s)	0.00	1.00	0.00	0.00
<b>Total Calculated Water Use (l/p/day)</b>					<b>114.81</b>
Grey/RainWater Reused (l)					0.00
Normalisation Factor (Factor)					0.91
<b>Total Consumption CSH (l/p/day)</b>					<b>104.47</b>
External Water Use Allowance (l)					5.00
<b>Total Consumption Part G (l/p/day)</b>					<b>109.47</b>

Assesment Result

**PASS**