

ALLOTMENTS BEYOND

Due to the close boundary proximity to the rear wall the external surface to this elevation will need to achieve a fire performance of Class B-s3, d2 or better (otherwise it is counted as 50% unprotected area).

Exits to be as wide as the stairs

Escape through fenced compound gates to be readily available


Advise gates moved so further away than 1800mm from window

Access to sports field to remain level

minimum 30-minute fire resisting enclosures to stores if considered places of special fire hazard. Will also require lobby separation from the stair, with 0.4m² permanent ventilation

Minimum 60 minutes compartmentation

Scale Bar 1:100



Aros

Aros Architects
Jerwood Space
171 Union Street
London SE1 0LN

Telephone
+44(0)20 7928 2444
Facsimile
+44(0)20 7928 2450

Email
info@arosarchitects.com
Website
www.arosarchitects.com

- Revisions
- | Rev | Date | Drawn | Checked | Description |
|----------|------|-------|---------|-------------|
| XX.XX.XX | | | | |
- All dimensions are to be verified by the Contractor on site, any discrepancies in this drawing are to be reported to Aros Ltd.
 - The Contractor shall not vary any work shown on this drawing without prior approval in writing from Aros Ltd.
 - The Contractor shall supply a full set of shop drawings and specifications prior to commencement of work.
 - This drawing supersedes all previous issues of the same drawing number with an earlier revision suffix.
 - The Contractor shall immediately inform Aros Ltd of the effect upon the programme and costs of any alterations to the proposed works shown on this drawing.
 - This drawing is the copyright of Aros Ltd and the contents must not be disclosed to other parties without prior agreement.

Project
HWRCC PAVILION
Title
PROPOSED GROUND FLOOR PLAN

Project No
6344
Date
MAY 2024
Status
PLANNING

Drawing No
(20) 100
Scale
1:100 @ A3
Rev
P3

