

## Project name

# Avalon House New Green Proposed Blinds 2013

As designed

Date: Thu May 23 21:55:21 2024

## Administrative information

## Building Details

Address: Address 1, City, Postcode

## Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.25

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.25

BRUKL compliance check version: v5.6.b.0

## Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

Criterion 1: The calculated CO<sub>2</sub> emission rate for the building must not exceed the target

|  |                     |
|--|---------------------|
| CO <sub>2</sub> emission rate from the notional building, kgCO <sub>2</sub> /m <sup>2</sup> .annum | 22.5                |
| Target CO <sub>2</sub> emission rate (TER), kgCO <sub>2</sub> /m <sup>2</sup> .annum               | 22.5                |
| Building CO <sub>2</sub> emission rate (BER), kgCO <sub>2</sub> /m <sup>2</sup> .annum             | 6                   |
| Are emissions from the building less than or equal to the target?                                  | BER =< TER          |
| Are as built details the same as used in the BER calculations?                                     | Separate submission |

## Criterion 2: The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Values which do not achieve the standards in the Non-Domestic Building Services Compliance Guide and Part L are displayed in red.

## Building fabric

| Element                                  | U <sub>a</sub> -Limit | U <sub>a</sub> -Calc | U <sub>i</sub> -Calc | Surface where the maximum value occurs*  |
|--|-----------------------|----------------------|----------------------|--|
| Wall**                                   | 0.35                  | 0.12                 | 0.12                 | L0000031:Surf[0]                         |
| Floor                                    | 0.25                  | 0.1                  | 0.1                  | L0000029:Surf[0]                         |
| Roof                                     | 0.25                  | 0.1                  | 0.1                  | L0000040:Surf[14]                        |
| Windows***, roof windows, and rooflights | 2.2                   | 1.26                 | 1.8                  | L0000040:Surf[2]                         |
| Personnel doors                          | 2.2                   | 1.6                  | 1.6                  | L000002A:Surf[0]                         |
| Vehicle access & similar large doors     | 1.5                   | -                    | -                    | No vehicle access doors in building      |
| High usage entrance doors                | 3.5                   | -                    | -                    | No high usage entrance doors in building |

U<sub>a</sub>-Limit = Limiting area-weighted average U-values [W/(m<sup>2</sup>K)]U<sub>a</sub>-Calc = Calculated area-weighted average U-values [W/(m<sup>2</sup>K)]U<sub>i</sub>-Calc = Calculated maximum individual element U-values [W/(m<sup>2</sup>K)]

\* There might be more than one surface where the maximum U-value occurs.

\*\* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

\*\*\* Display windows and similar glazing are excluded from the U-value check.

N.B.: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air Permeability                             | Worst acceptable standard | This building |
|--|---------------------------|---------------|
| m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa | 10                        | 3             |

## Building services

The standard values listed below are minimum values for efficiencies and maximum values for SFPs. Refer to the Non-Domestic Building Services Compliance Guide for details.

|  |       |
|--|-------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES   |
| Whole building electric power factor achieved by power factor correction                     | >0.95 |

### 1- 04\_Rad\_Elec\_MV

|  | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| <b>This system</b>   | 1                  | -                  | 0.3                | -             | 0.75          |
| <b>Standard value</b>  | N/A                | N/A                | N/A                | N/A           | 0.5           |
| <b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b> |                    |                    |                    |               | YES           |

### 2- 03\_GF01\_FCU\_ASHP\_GF

|   | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|---|--------------------|--------------------|--------------------|---------------|---------------|
| <b>This system</b>  | 3.62               | 3.76               | 0                  | 1.6           | 0.8           |
| <b>Standard value</b>   | 2.5*               | 3.2                | N/A                | 1.6^          | 0.65          |
| <b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>  |                    |                    |                    |               | YES           |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. For types <=12 kW output, refer to EN 14825 for limiting standards.                   |                    |                    |                    |               |               |
| ^ Limiting SFP may be extended by the amounts specified in the Non-Domestic Building Services Compliance Guide if the system includes additional components as listed in the Guide. |                    |                    |                    |               |               |

### 3- 06\_Rad\_Elec\_NV

|  | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| <b>This system</b>   | 1                  | -                  | 0.3                | -             | -             |
| <b>Standard value</b>  | N/A                | N/A                | N/A                | N/A           | N/A           |
| <b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b> |                    |                    |                    |               | YES           |

### 4- 02\_TH\_ASHP\_Perimeter Offices\_UF

|   | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|---|--------------------|--------------------|--------------------|---------------|---------------|
| <b>This system</b>  | 3.62               | 3.76               | 0                  | 1.6           | 0.8           |
| <b>Standard value</b>   | 2.5*               | 2.55               | N/A                | 1.6^          | 0.65          |
| <b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>  |                    |                    |                    |               | YES           |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. For types <=12 kW output, refer to EN 14825 for limiting standards.                   |                    |                    |                    |               |               |
| ^ Limiting SFP may be extended by the amounts specified in the Non-Domestic Building Services Compliance Guide if the system includes additional components as listed in the Guide. |                    |                    |                    |               |               |

### 5- 01\_AHU\_ASHP\_DV\_Internal Offices\_UF

|   | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|---|--------------------|--------------------|--------------------|---------------|---------------|
| <b>This system</b>  | 3.62               | 3.76               | 0                  | 1.6           | 0.8           |
| <b>Standard value</b>   | 2.5*               | 2.55               | N/A                | 1.6^          | 0.65          |
| <b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>  |                    |                    |                    |               | YES           |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. For types <=12 kW output, refer to EN 14825 for limiting standards.                   |                    |                    |                    |               |               |
| ^ Limiting SFP may be extended by the amounts specified in the Non-Domestic Building Services Compliance Guide if the system includes additional components as listed in the Guide. |                    |                    |                    |               |               |

"No HWS in project, or hot water is provided by HVAC system"

**Local mechanical ventilation, exhaust, and terminal units**

| ID | System type in Non-domestic Building Services Compliance Guide  |
|----|---|
| A  | Local supply or extract ventilation units serving a single area   |
| B  | Zonal supply system where the fan is remote from the zone   |
| C  | Zonal extract system where the fan is remote from the zone  |
| D  | Zonal supply and extract ventilation units serving a single room or zone with heating and heat recovery |
| E  | Local supply and extract ventilation system serving a single area with heating and heat recovery        |
| F  | Other local ventilation units   |
| G  | Fan-assisted terminal VAV unit  |
| H  | Fan coil units  |
| I  | Zonal extract system where the fan is remote from the zone with grease filter                           |

| Zone name           | ID of system type | SFP [W/(l/s)]  |     |     |     |     |     |     |     |     | HR efficiency |          |
|---------------------|-------------------|----------------|-----|-----|-----|-----|-----|-----|-----|-----|---------------|----------|
|                     |                   | A              | B   | C   | D   | E   | F   | G   | H   | I   | Zone          | Standard |
|                     |                   | Standard value | 0.3 | 1.1 | 0.5 | 1.9 | 1.6 | 0.5 | 1.1 | 0.5 |               |          |
| L01-WC Lobby 1      | -                 | -              | -   | 1.6 | -   | -   | -   | -   | -   | -   | -             | N/A      |
| L01-WC Lobby 2      | -                 | -              | -   | 1.6 | -   | -   | -   | -   | -   | -   | -             | N/A      |
| L02-WC Lobby 1      | -                 | -              | -   | 1.6 | -   | -   | -   | -   | -   | -   | -             | N/A      |
| L02-WC Lobby 2      | -                 | -              | -   | 1.6 | -   | -   | -   | -   | -   | -   | -             | N/A      |
| L03-Acc WC          | -                 | -              | -   | 1.6 | -   | -   | -   | -   | -   | -   | -             | N/A      |
| L03-Lift Lobby      | -                 | -              | -   | -   | -   | -   | -   | 0.2 | -   | -   | -             | N/A      |
| L03-WC              | -                 | -              | -   | 1.6 | -   | -   | -   | -   | -   | -   | -             | N/A      |
| L03-WC Lobby 1      | -                 | -              | -   | 1.6 | -   | -   | -   | -   | -   | -   | -             | N/A      |
| L03-WC Lobby 2      | -                 | -              | -   | 1.6 | -   | -   | -   | -   | -   | -   | -             | N/A      |
| L03-Office PER3     | -                 | -              | -   | -   | -   | -   | -   | 0.2 | -   | -   | -             | N/A      |
| L04-Office PER2     | -                 | -              | -   | -   | -   | -   | -   | 0.2 | -   | -   | -             | N/A      |
| L04-Office PER2     | -                 | -              | -   | -   | -   | -   | -   | 0.2 | -   | -   | -             | N/A      |
| L04-Plant           | -                 | -              | -   | 1.6 | -   | -   | -   | -   | -   | -   | -             | N/A      |
| L04-Circulation     | -                 | -              | -   | -   | -   | -   | -   | 0.2 | -   | -   | -             | N/A      |
| L04-Office PER1     | -                 | -              | -   | -   | -   | -   | -   | 0.2 | -   | -   | -             | N/A      |
| L04-Lift Lobby      | -                 | -              | -   | -   | -   | -   | -   | 0.2 | -   | -   | -             | N/A      |
| L04-WC Lobby 1      | -                 | -              | -   | 1.6 | -   | -   | -   | -   | -   | -   | -             | N/A      |
| L04-WC              | -                 | -              | -   | 1.6 | -   | -   | -   | -   | -   | -   | -             | N/A      |
| L00-WC Lobby 1      | -                 | -              | -   | 1.6 | -   | -   | -   | -   | -   | -   | -             | N/A      |
| L00-Office 1-New    | -                 | -              | -   | -   | -   | -   | -   | 0.2 | -   | -   | -             | N/A      |
| L01-Office PER4-New | -                 | -              | -   | -   | -   | -   | -   | 0.2 | -   | -   | -             | N/A      |
| L03-Office PER2     | -                 | -              | -   | -   | -   | -   | -   | 0.2 | -   | -   | -             | N/A      |
| L03-Office PER2     | -                 | -              | -   | -   | -   | -   | -   | 0.2 | -   | -   | -             | N/A      |
| L03-Office PER1     | -                 | -              | -   | -   | -   | -   | -   | 0.2 | -   | -   | -             | N/A      |
| L03-Office PER1     | -                 | -              | -   | -   | -   | -   | -   | 0.2 | -   | -   | -             | N/A      |
| L03-Office PER1     | -                 | -              | -   | -   | -   | -   | -   | 0.2 | -   | -   | -             | N/A      |

**General lighting and display lighting**

| Zone name             | Luminous efficacy [lm/W] |      |              | General lighting [W] |
|-----------------------|--------------------------|------|--------------|----------------------|
|                       | Luminaire                | Lamp | Display lamp |                      |
| <b>Standard value</b> | 60                       | 60   | 22           |                      |
| L01-WC Lobby 1        | -                        | 120  | -            | 28                   |

| General lighting and display lighting |                | Luminous efficacy [lm/W] |      |              | General lighting [W] |
|---------------------------------------|----------------|--------------------------|------|--------------|----------------------|
| Zone name                             | Standard value | Luminaire                | Lamp | Display lamp |                      |
|                                       | 60             | 60                       | 22   |              |                      |
| L01-WC Lobby 2                        | -              | 120                      | -    |              | 28                   |
| L02-WC Lobby 1                        | -              | 120                      | -    |              | 27                   |
| L02-WC Lobby 2                        | -              | 120                      | -    |              | 27                   |
| L03-Acc WC                            | -              | 120                      | -    |              | 37                   |
| L03-Lift Lobby                        | -              | 120                      | -    |              | 38                   |
| L03-Stairs 01                         | -              | 120                      | -    |              | 35                   |
| L03-Stairs 02                         | -              | 120                      | -    |              | 30                   |
| L03-Stairs 03                         | -              | 120                      | -    |              | 30                   |
| L03-WC                                | -              | 120                      | -    |              | 76                   |
| L03-WC Lobby 1                        | -              | 120                      | -    |              | 28                   |
| L03-WC Lobby 2                        | -              | 120                      | -    |              | 28                   |
| L04-Stairs 03                         | -              | 120                      | -    |              | 30                   |
| L03-Office PER3                       | 140            | -                        | -    |              | 306                  |
| L04-Office PER2                       | 141            | -                        | -    |              | 493                  |
| L04-Office PER2                       | 358            | -                        | -    |              | 21                   |
| L04-Plant                             | 120            | -                        | -    |              | 55                   |
| L04-Circulation                       | -              | 120                      | -    |              | 32                   |
| L04-Office PER1                       | 132            | -                        | -    |              | 590                  |
| L04-Office CORE                       | 133            | -                        | -    |              | 330                  |
| L04-Stairs 01                         | -              | 120                      | -    |              | 35                   |
| L04-Lift Lobby                        | -              | 120                      | -    |              | 38                   |
| L04-WC Lobby 1                        | -              | 120                      | -    |              | 27                   |
| L04-WC                                | -              | 120                      | -    |              | 40                   |
| L00-WC Lobby 1                        | -              | 120                      | -    |              | 40                   |
| L00-Office 1-New                      | 138            | -                        | -    |              | 241                  |
| L01-Office PER4-New                   | 137            | -                        | -    |              | 241                  |
| L03-Office PER2                       | 142            | -                        | -    |              | 188                  |
| L03-Office PER2                       | 136            | -                        | -    |              | 277                  |
| L03-Office PER1                       | 136            | -                        | -    |              | 431                  |
| L03-Office PER1                       | 134            | -                        | -    |              | 93                   |
| L03-Office PER1                       | 135            | -                        | -    |              | 634                  |
| L03-Office CORE 1                     | 135            | -                        | -    |              | 596                  |

**Criterion 3: The spaces in the building should have appropriate passive control measures to limit solar gains**

| Zone            | Solar gain limit exceeded? (%) | Internal blinds used? |
|-----------------|--------------------------------|-----------------------|
| L03-Lift Lobby  | N/A                            | N/A                   |
| L03-Office PER3 | NO (-92%)                      | YES                   |
| L04-Office PER2 | NO (-90.5%)                    | YES                   |
| L04-Office PER2 | N/A                            | N/A                   |
| L04-Circulation | N/A                            | N/A                   |
| L04-Office PER1 | NO (-72.6%)                    | YES                   |
| L04-Office CORE | N/A                            | N/A                   |
| L04-Lift Lobby  | NO (-71.7%)                    | YES                   |

| Zone                | Solar gain limit exceeded? (%) | Internal blinds used? |
|---------------------|--------------------------------|-----------------------|
| L00-Office 1-New    | NO (-93.2%)                    | YES                   |
| L01-Office PER4-New | NO (-94%)                      | YES                   |
| L03-Office PER2     | NO (-88.6%)                    | YES                   |
| L03-Office PER2     | NO (-85.6%)                    | YES                   |
| L03-Office PER1     | NO (-93.9%)                    | YES                   |
| L03-Office PER1     | NO (-83.8%)                    | YES                   |
| L03-Office PER1     | NO (-92.8%)                    | YES                   |
| L03-Office CORE 1   | N/A                            | N/A                   |

**Criterion 4: The performance of the building, as built, should be consistent with the calculated BER**

Separate submission

**Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place**

Separate submission

**EPBD (Recast): Consideration of alternative energy systems**

|   |           |
|---|-----------|
| <b>Were alternative energy systems considered and analysed as part of the design process?</b> | <b>NO</b> |
| Is evidence of such assessment available as a separate submission?                            | NO        |
| Are any such measures included in the proposed design?  | NO        |

# Technical Data Sheet (Actual vs. Notional Building)

## Building Global Parameters

|   | Actual | Notional |
|---|--------|----------|
| Area [m <sup>2</sup> ]                                | 1292.4 | 1292.4   |
| External area [m <sup>2</sup> ]                       | 1807.4 | 1807.4   |
| Weather   | LON    | LON      |
| Infiltration [m <sup>3</sup> /hm <sup>2</sup> @ 50Pa] | 3      | 3        |
| Average conductance [W/K]                             | 611.83 | 872.36   |
| Average U-value [W/m <sup>2</sup> K]                  | 0.34   | 0.48     |
| Alpha value* [%]                                      | 8.81   | 10       |

\* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

## Building Use

### % Area Building Type

|            |  |
|------------|--|
|            | A1/A2 Retail/Financial and Professional services                   |
|            | A3/A4/A5 Restaurants and Cafes/Drinking Est./Takeaways             |
| <b>100</b> | <b>B1 Offices and Workshop businesses</b>                          |
|            | B2 to B7 General Industrial and Special Industrial Groups          |
|            | B8 Storage or Distribution   |
|            | C1 Hotels  |
|            | C2 Residential Institutions: Hospitals and Care Homes              |
|            | C2 Residential Institutions: Residential schools                   |
|            | C2 Residential Institutions: Universities and colleges             |
|            | C2A Secure Residential Institutions                                |
|            | Residential spaces   |
|            | D1 Non-residential Institutions: Community/Day Centre              |
|            | D1 Non-residential Institutions: Libraries, Museums, and Galleries |
|            | D1 Non-residential Institutions: Education                         |
|            | D1 Non-residential Institutions: Primary Health Care Building      |
|            | D1 Non-residential Institutions: Crown and County Courts           |
|            | D2 General Assembly and Leisure, Night Clubs, and Theatres         |
|            | Others: Passenger terminals  |
|            | Others: Emergency services   |
|            | Others: Miscellaneous 24hr activities                              |
|            | Others: Car Parks 24 hrs   |
|            | Others: Stand alone utility block                                  |

## Energy Consumption by End Use [kWh/m<sup>2</sup>]

|                | Actual      | Notional     |
|----------------|-------------|--------------|
| Heating        | 5.28        | 7.31         |
| Cooling        | 3.38        | 7.15         |
| Auxiliary      | 9.31        | 10.74        |
| Lighting       | 5.86        | 19.41        |
| Hot water      | 2.37        | 2.48         |
| Equipment*     | 36.96       | 36.96        |
| <b>TOTAL**</b> | <b>26.2</b> | <b>47.08</b> |

\* Energy used by equipment does not count towards the total for consumption or calculating emissions.

\*\* Total is net of any electrical energy displaced by CHP generators, if applicable.

## Energy Production by Technology [kWh/m<sup>2</sup>]

|                       | Actual | Notional |
|-----------------------|--------|----------|
| Photovoltaic systems  | 13.96  | 0        |
| Wind turbines         | 0      | 0        |
| CHP generators        | 0      | 0        |
| Solar thermal systems | 0      | 0        |

## Energy & CO<sub>2</sub> Emissions Summary

|   | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m <sup>2</sup> ] | 75.8   | 137.56   |
| Primary energy* [kWh/m <sup>2</sup> ]         | 78.44  | 127.77   |
| Total emissions [kg/m <sup>2</sup> ]          | 6      | 22.5     |

\* Primary energy is net of any electrical energy displaced by CHP generators, if applicable.

## HVAC Systems Performance

| System Type   | Heat dem<br>MJ/m2 | Cool dem<br>MJ/m2 | Heat con<br>kWh/m2 | Cool con<br>kWh/m2 | Aux con<br>kWh/m2 | Heat<br>SSEFF | Cool<br>SSEER | Heat gen<br>SEFF | Cool gen<br>SEER |
|---|-------------------|-------------------|--------------------|--------------------|-------------------|---------------|---------------|------------------|------------------|
| <b>[ST] Fan coil systems, [HS] Heat pump (electric): air source, [HFT] Electricity, [CFT] Electricity</b>                                 |                   |                   |                    |                    |                   |               |               |                  |                  |
| <b>Actual</b>   | 32.5              | 45.3              | 2.7                | 4.2                | 8.4               | 3.34          | 3.01          | 3.62             | 3.76             |
| <b>Notional</b>   | 62.5              | 119.1             | 6.8                | 8.7                | 14.3              | 2.56          | 3.79          | ----             | ----             |
| <b>[ST] Constant volume system (variable fresh air rate), [HS] Heat pump (electric): air source, [HFT] Electricity, [CFT] Electricity</b> |                   |                   |                    |                    |                   |               |               |                  |                  |
| <b>Actual</b>   | 27.3              | 46.8              | 1.8                | 5.3                | 19.1              | 4.24          | 2.45          | 3.62             | 3.76             |
| <b>Notional</b>   | 16.2              | 122.8             | 1.8                | 9                  | 11.6              | 2.56          | 3.79          | ----             | ----             |
| <b>[ST] Fan coil systems, [HS] Heat pump (electric): air source, [HFT] Electricity, [CFT] Electricity</b>                                 |                   |                   |                    |                    |                   |               |               |                  |                  |
| <b>Actual</b>   | 44.9              | 40.7              | 3.7                | 3.8                | 8.5               | 3.34          | 3.01          | 3.62             | 3.76             |
| <b>Notional</b>   | 31.6              | 117.3             | 3.4                | 8.6                | 12.9              | 2.56          | 3.79          | ----             | ----             |
| <b>[ST] Other local room heater - unfanned, [HS] Direct or storage electric heater, [HFT] Electricity, [CFT] Electricity</b>              |                   |                   |                    |                    |                   |               |               |                  |                  |
| <b>Actual</b>   | 100.3             | 0                 | 33.1               | 0                  | 0                 | 0.84          | 0             | 1                | 0                |
| <b>Notional</b>   | 164.8             | 0                 | 53.1               | 0                  | 0                 | 0.86          | 0             | ----             | ----             |
| <b>[ST] Other local room heater - unfanned, [HS] Direct or storage electric heater, [HFT] Electricity, [CFT] Electricity</b>              |                   |                   |                    |                    |                   |               |               |                  |                  |
| <b>Actual</b>   | 7.4               | 0                 | 2.4                | 0                  | 5.9               | 0.84          | 0             | 1                | 0                |
| <b>Notional</b>   | 20.6              | 0                 | 6.6                | 0                  | 2.1               | 0.86          | 0             | ----             | ----             |

### Key to terms

|                   |   |
|-------------------|---|
| Heat dem [MJ/m2]  | = Heating energy demand   |
| Cool dem [MJ/m2]  | = Cooling energy demand   |
| Heat con [kWh/m2] | = Heating energy consumption  |
| Cool con [kWh/m2] | = Cooling energy consumption  |
| Aux con [kWh/m2]  | = Auxiliary energy consumption  |
| Heat SSEFF        | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER        | = Cooling system seasonal energy efficiency ratio   |
| Heat gen SSEFF    | = Heating generator seasonal efficiency   |
| Cool gen SSEER    | = Cooling generator seasonal energy efficiency ratio  |
| ST                | = System type   |
| HS                | = Heat source   |
| HFT               | = Heating fuel type   |
| CFT               | = Cooling fuel type   |

# Key Features

The Building Control Body is advised to give particular attention to items whose specifications are better than typically expected.

## Building fabric

| Element  | U <sub>i-Typ</sub> | U <sub>i-Min</sub> | Surface where the minimum value occurs*  |
|--|--------------------|--------------------|--|
| Wall   | 0.23               | 0.12               | L0000031:Surf[0]                         |
| Floor  | 0.2                | 0.1                | L0000029:Surf[0]                         |
| Roof   | 0.15               | 0.1                | L0000040:Surf[14]                        |
| Windows, roof windows, and rooflights  | 1.5                | 1                  | L000001E:Surf[0]                         |
| Personnel doors  | 1.5                | 1.6                | L000002A:Surf[0]                         |
| Vehicle access & similar large doors   | 1.5                | -                  | No vehicle access doors in building      |
| High usage entrance doors  | 1.5                | -                  | No high usage entrance doors in building |
| U <sub>i-Typ</sub> = Typical individual element U-values [W/(m <sup>2</sup> K)]      U <sub>i-Min</sub> = Minimum individual element U-values [W/(m <sup>2</sup> K)]<br>* There might be more than one surface where the minimum U-value occurs. |                    |                    |  |

| Air Permeability                             | Typical value | This building |
|--|---------------|---------------|
| m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa | 5             | 3             |