

Project name

**Avalon House Refurb Baseline 2021**

As designed

Date: Fri May 24 10:44:43 2024

**Administrative information****Building Details**

Address: Address 1, City, Postcode

**Certifier details**

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

**Certification tool**

Calculation engine: Apache

Calculation engine version: 7.0.25

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.25

BRUKL compliance module version: v6.1.e.1

Foundation area [m<sup>2</sup>]: 940.34**The CO<sub>2</sub> emission and primary energy rates of the building must not exceed the targets**

The building does not comply with England Building Regulations Part L 2021

Target CO <sub>2</sub> emission rate (TER), kgCO <sub>2</sub> /m <sup>2</sup> annum	4.71
Building CO <sub>2</sub> emission rate (BER), kgCO <sub>2</sub> /m <sup>2</sup> annum	8.61
Target primary energy rate (TPER), kWh <sub>PE</sub> /m <sup>2</sup> annum	51.1
Building primary energy rate (BPER), kWh <sub>PE</sub> /m <sup>2</sup> annum	92.86
Do the building's emission and primary energy rates exceed the targets?	BER > TER   BPER > TPER

**The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency**

Fabric element	U <sub>a</sub> -Limit	U <sub>a</sub> -Calc	U <sub>i</sub> -Calc	First surface with maximum value
Walls*	0.26	0.3	0.3	TP000013:Surf[1]
Floors	0.18	0.25	0.25	TP000013:Surf[0]
Pitched roofs	0.16	-	-	No pitched roofs in building
Flat roofs	0.18	0.1	0.1	L0000001:Surf[0]
Windows** and roof windows	1.6	1.4	1.4	TP000007:Surf[2]
Rooflights***	2.2	-	-	No roof lights in building
Personnel doors <sup>^</sup>	1.6	1.6	1.6	TP000015:Surf[1]
Vehicle access & similar large doors	1.3	-	-	No vehicle access doors in building
High usage entrance doors	3	-	-	No high usage entrance doors in building

U<sub>a</sub>-Limit = Limiting area-weighted average U-values [W/(m<sup>2</sup>K)]U<sub>a</sub>-Calc = Calculated area-weighted average U-values [W/(m<sup>2</sup>K)]U<sub>i</sub>-Calc = Calculated maximum individual element U-values [W/(m<sup>2</sup>K)]

\* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

\*\* Display windows and similar glazing are excluded from the U-value check. \*\*\* Values for rooflights refer to the horizontal position.

<sup>^</sup> For fire doors, limiting U-value is 1.8 W/m<sup>2</sup>K

NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

Air permeability	Limiting standard	This building
m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa	8	15

## Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

<b>Whole building lighting automatic monitoring &amp; targeting with alarms for out-of-range values</b>	YES
<b>Whole building electric power factor achieved by power factor correction</b>	>0.95

### 1- 03\_GF01\_FCU\_ASHP\_GF

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	2.5	3	0	2.6	0.7
<b>Standard value</b>	2.5*	N/A	N/A	2^	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					
^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.					

### 2- 04\_Rad\_Elec\_MV

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	1	-	0.3	-	0.7
<b>Standard value</b>	N/A	N/A	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES

### 3- 06\_Rad\_Elec\_NV

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	1	-	0.3	-	-
<b>Standard value</b>	N/A	N/A	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES

### 4- 01\_AHU\_ASHP\_DV\_Internal Offices\_UF

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	2.5	3	0	2.6	0.7
<b>Standard value</b>	2.5*	4.5**	N/A	2^	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					
** Standard shown is for air-cooled chillers >=400 kW. For chillers <400 kW, limiting SEER is 4.					
^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.					

### 5- 02\_TH\_ASHP\_Perimeter Offices\_UF

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	2.5	3	0	2.6	0.7
<b>Standard value</b>	2.5*	4.5**	N/A	2^	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					
** Standard shown is for air-cooled chillers >=400 kW. For chillers <400 kW, limiting SEER is 4.					
^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.					

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	2.5	5	-	-	0.7
<b>Standard value</b>	2.5*	5	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					

"No HWS in project, or hot water is provided by HVAC system"

#### Zone-level mechanical ventilation, exhaust, and terminal units

ID	System type in the Approved Documents
A	Local supply or extract ventilation units
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal balanced supply and extract ventilation system
E	Local balanced supply and extract ventilation units
F	Other local ventilation units
G	Fan assisted terminal variable air volume units
H	Fan coil units
I	Kitchen extract with the fan remote from the zone and a grease filter

NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

Zone name	SFP [W/(l/s)]										HR efficiency	
	ID of system type	A	B	C	D	E	F	G	H	I	Zone	Standard
	<b>Standard value</b>	0.3	1.1	0.5	2.3	2	0.5	0.5	0.4	1		
L00-Building Management		-	-	-	-	-	-	-	0.4	-	-	N/A
L00-Water Plant		-	-	-	2.6	-	-	-	-	-	-	N/A
L00-Lift Lobby		-	-	-	-	-	-	-	0.4	-	-	N/A
L00-LV Switch		-	-	-	2.6	-	-	-	-	-	-	N/A
L00-Office 2		-	-	-	-	-	-	-	0.4	-	-	N/A
L00-Reception		-	-	-	-	-	-	-	0.4	-	-	N/A
L00-WC		-	-	-	2.6	-	-	-	-	-	-	N/A
L01-Acc WC		-	-	-	2.6	-	-	-	-	-	-	N/A
L01-Lift Lobby		-	-	-	-	-	-	-	0.4	-	-	N/A
L01-WC		-	-	-	2.6	-	-	-	-	-	-	N/A
L01-WC Lobby 1		-	-	-	2.6	-	-	-	-	-	-	N/A
L01-WC Lobby 2		-	-	-	2.6	-	-	-	-	-	-	N/A
L02-Acc WC		-	-	-	2.6	-	-	-	-	-	-	N/A
L02-Lift Lobby		-	-	-	-	-	-	-	0.4	-	-	N/A
L02-Office PER3		-	-	-	-	-	-	-	0.4	-	-	N/A
L02-Office PER4		-	-	-	-	-	-	-	0.4	-	-	N/A
L02-WC		-	-	-	2.6	-	-	-	-	-	-	N/A
L02-WC Lobby 1		-	-	-	2.6	-	-	-	-	-	-	N/A
L02-WC Lobby 2		-	-	-	2.6	-	-	-	-	-	-	N/A
L00-Substation		-	-	-	2.6	-	-	-	-	-	-	N/A
L01-Office PER2		-	-	-	-	-	-	-	0.4	-	-	N/A
L01-Office PER1		-	-	-	-	-	-	-	0.4	-	-	N/A

Zone name	SFP [W/(l/s)]										HR efficiency	
	ID of system type	A	B	C	D	E	F	G	H	I	Zone	Standard
Standard value	0.3	1.1	0.5	2.3	2	0.5	0.5	0.4	1			
L02-Office PER2	-	-	-	-	-	-	-	0.4	-	-	-	N/A
L02-Office PER1	-	-	-	-	-	-	-	0.4	-	-	-	N/A
L02-Office PER5	-	-	-	-	-	-	-	0.4	-	-	-	N/A
L00-Acc Shower	-	-	-	2.6	-	-	-	-	-	-	-	N/A
L00-Cleaners	-	-	-	2.6	-	-	-	-	-	-	-	N/A
L00-WC Lobby 1	-	-	-	2.6	-	-	-	-	-	-	-	N/A
L00-Changing 1	-	-	-	2.6	-	-	-	-	-	-	-	N/A
L00-Showers 1	-	-	-	2.6	-	-	-	-	-	-	-	N/A
L00-Showers 2	-	-	-	2.6	-	-	-	-	-	-	-	N/A
L00-Changing 2	-	-	-	2.6	-	-	-	-	-	-	-	N/A
L00-Comms	-	-	-	2.6	-	-	-	-	-	-	-	N/A
L00-AHU	-	-	-	2.6	-	-	-	-	-	-	-	N/A
L00-Cycle Store	-	-	-	-	-	-	-	0.4	-	-	-	N/A
L00-Office 1	-	-	-	-	-	-	-	0.4	-	-	-	N/A
L01-Office PER4	-	-	-	-	-	-	-	0.4	-	-	-	N/A
L01-Office PER4	-	-	-	-	-	-	-	0.4	-	-	-	N/A
L01-Office PER3	-	-	-	-	-	-	-	0.4	-	-	-	N/A

General lighting and display lighting		General luminaire	Display light source	
Zone name	Efficacy [lm/W]	Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m <sup>2</sup> ]
Standard value	95	80	0.3	
L00-Building Management	60	-	-	
L00-Water Plant	60	-	-	
L00-Lift Lobby	60	-	-	
L00-LV Switch	60	-	-	
L00-Office 2	60	-	-	
L00-Reception	60	120	1.125	
L00-Stairs 01	60	-	-	
L00-Stairs 02	60	-	-	
L00-Stairs 03	60	-	-	
L00-WC	60	-	-	
L01-Acc WC	60	-	-	
L01-Lift Lobby	60	-	-	
L01-Stairs 01	60	-	-	
L01-Stairs 02	60	-	-	
L01-Stairs 03	60	-	-	
L01-WC	60	-	-	
L01-WC Lobby 1	60	-	-	
L01-WC Lobby 2	60	-	-	
L02-Acc WC	60	-	-	
L02-Lift Lobby	60	-	-	
L02-Office CORE 2	60	-	-	
L02-Office PER3	60	-	-	

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m <sup>2</sup> ]
	<b>Standard value</b>	95	80	0.3
L02-Office PER4		60	-	-
L02-Stairs 01		60	-	-
L02-Stairs 02		60	-	-
L02-Stairs 03		60	-	-
L02-WC		60	-	-
L02-WC Lobby 1		60	-	-
L02-WC Lobby 2		60	-	-
L00-Substation		60	-	-
L01-Office PER2		60	-	-
L01-Office PER1		60	-	-
L02-Office PER2		60	-	-
L02-Office PER1		60	-	-
L02-Office PER5		60	-	-
L02-Office CORE 1		60	-	-
L00-Acc Shower		60	-	-
L00-Cleaners		60	-	-
L00-WC Lobby 1		60	-	-
L00-Changing 1		60	-	-
L00-Showers 1		60	-	-
L00-Showers 2		60	-	-
L00-Changing 2		60	-	-
L00-Comms		60	-	-
L00-AHU		60	-	-
L00-Cycle Store		60	-	-
L00-Office 1		60	-	-
L01-Office PER4		60	-	-
L01-Office CORE		60	-	-
L01-Office PER4		60	-	-
L01-Office PER3		60	-	-

**The spaces in the building should have appropriate passive control measures to limit solar gains in summer**

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
L00-Building Management	N/A	N/A
L00-Lift Lobby	YES (+110.5%)	NO
L00-Office 2	NO (-39.8%)	NO
L00-Reception	YES (+31.9%)	NO
L01-Lift Lobby	N/A	N/A
L02-Lift Lobby	N/A	N/A
L02-Office CORE 2	NO (-14.5%)	NO
L02-Office PER3	NO (-6.2%)	NO
L02-Office PER4	NO (-19.9%)	NO
L01-Office PER2	NO (-10.3%)	NO
L01-Office PER1	NO (-48.1%)	NO

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
L02-Office PER2	YES (+30.6%)	NO
L02-Office PER1	NO (-30.6%)	NO
L02-Office PER5	NO (-6.2%)	NO
L02-Office CORE 1	YES (+145.9%)	NO
L00-Comms	N/A	N/A
L00-Cycle Store	N/A	N/A
L00-Office 1	NO (-56.4%)	NO
L01-Office PER4	NO (-59.6%)	NO
L01-Office CORE	YES (+176.9%)	NO
L01-Office PER4	NO (-79%)	NO
L01-Office PER3	NO (-40.9%)	NO

## Regulation 25A: Consideration of high efficiency alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	NO
Is evidence of such assessment available as a separate submission?	NO
Are any such measures included in the proposed design?	NO

# Technical Data Sheet (Actual vs. Notional Building)

## Building Global Parameters

	Actual	Notional
Floor area [m <sup>2</sup> ]	2821	2821
External area [m <sup>2</sup> ]	3075.9	3075.9
Weather	LON	LON
Infiltration [m <sup>3</sup> /hm <sup>2</sup> @ 50Pa]	15	3
Average conductance [W/K]	1424.41	1355.61
Average U-value [W/m <sup>2</sup> K]	0.46	0.44
Alpha value* [%]	24.84	10

\* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

## Building Use

### % Area Building Type

	Retail/Financial and Professional Services
	Restaurants and Cafes/Drinking Establishments/Takeaways
<b>100</b>	<b>Offices and Workshop Businesses</b>
	General Industrial and Special Industrial Groups
	Storage or Distribution
	Hotels
	Residential Institutions: Hospitals and Care Homes
	Residential Institutions: Residential Schools
	Residential Institutions: Universities and Colleges
	Secure Residential Institutions
	Residential Spaces
	Non-residential Institutions: Community/Day Centre
	Non-residential Institutions: Libraries, Museums, and Galleries
	Non-residential Institutions: Education
	Non-residential Institutions: Primary Health Care Building
	Non-residential Institutions: Crown and County Courts
	General Assembly and Leisure, Night Clubs, and Theatres
	Others: Passenger Terminals
	Others: Emergency Services
	Others: Miscellaneous 24hr Activities
	Others: Car Parks 24 hrs
	Others: Stand Alone Utility Block

## Energy Consumption by End Use [kWh/m<sup>2</sup>]

	Actual	Notional
Heating	15.3	3.75
Cooling	6.07	3.75
Auxiliary	15.27	7.75
Lighting	14.25	11.12
Hot water	11.71	10.57
Equipment*	46.66	46.66
<b>TOTAL**</b>	<b>62.6</b>	<b>36.94</b>

\* Energy used by equipment does not count towards the total for consumption or calculating emissions.

\*\* Total is net of any electrical energy displaced by CHP generators, if applicable.

## Energy Production by Technology [kWh/m<sup>2</sup>]

	Actual	Notional
Photovoltaic systems	0	2.34
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0
<i>Displaced electricity</i>	<i>0</i>	<i>2.34</i>

## Energy & CO<sub>2</sub> Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m <sup>2</sup> ]	142.31	90.7
Primary energy [kWh <sub>PE</sub> /m <sup>2</sup> ]	92.86	51.1
Total emissions [kg/m <sup>2</sup> ]	8.61	4.71

## HVAC Systems Performance

System Type	Heat dem MJ/m2	Cool dem MJ/m2	Heat con kWh/m2	Cool con kWh/m2	Aux con kWh/m2	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER
<b>[ST] Fan coil systems, [HS] ASHP, [HFT] Electricity, [CFT] Electricity</b>									
Actual	118.5	42.1	13.4	5.3	12.1	2.45	2.23	2.5	3
Notional	25	69.7	2.5	4.2	8.8	2.78	4.63	----	----
<b>[ST] Constant volume system (variable fresh air rate), [HS] ASHP, [HFT] Electricity, [CFT] Electricity</b>									
Actual	53.4	67.6	4.5	11.6	39.1	3.27	1.62	2.5	3
Notional	11.4	91.3	1.1	5.5	8.9	2.78	4.63	----	----
<b>[ST] Fan coil systems, [HS] ASHP, [HFT] Electricity, [CFT] Electricity</b>									
Actual	93	59.9	10.5	7.5	14.3	2.45	2.23	2.5	3
Notional	25.4	76.8	2.5	4.6	10	2.78	4.63	----	----
<b>[ST] Other local room heater - unfanned, [HS] Direct or storage electric heater, [HFT] Electricity, [CFT] Electricity</b>									
Actual	238.1	0	78.5	0	0	0.84	0	1	0
Notional	140.9	0	27.7	0	0	1.41	0	----	----
<b>[ST] Other local room heater - unfanned, [HS] Direct or storage electric heater, [HFT] Electricity, [CFT] Electricity</b>									
Actual	59.7	0	19.7	0	5.6	0.84	0	1	0
Notional	15.1	0	3	0	0.7	1.41	0	----	----
<b>[ST] Split or multi-split system, [HS] ASHP, [HFT] Electricity, [CFT] Electricity</b>									
Actual	0	0	0	0	0	2.45	3.74	2.5	5
Notional	0	0	0	0	0	2.78	4.63	----	----

### Key to terms

Heat dem [MJ/m2]	= Heating energy demand
Cool dem [MJ/m2]	= Cooling energy demand
Heat con [kWh/m2]	= Heating energy consumption
Cool con [kWh/m2]	= Cooling energy consumption
Aux con [kWh/m2]	= Auxiliary energy consumption
Heat SSEFF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type