

<b>Project</b>	13494 Hampton Pre-Prep School		
<b>Date</b>	8 March 2024	<b>Memo No</b>	M001
<b>Memo to</b>	Verity Moria, Hampton School		
<b>From</b>	Ian Rees MIOA	<b>Checked by</b>	Andy Thompson MIOA

## HALL EXTENSION - CHANGES TO LINK SECTION

We were appointed by Hampton School in 2022 to assess changes in activity noise arising from a proposed multi-purpose hall extension. Our noise assessment is set out in report 13494/1C dated 17 November 2022.

Our report concluded that there would be relatively little change in breakout levels at the nearest residences from the proposed development, with breakout noise varying by approximately +/- 1 dB(A). A change of 1 dB(A) is unlikely to be perceptible and therefore the proposed development is likely to have a minimal noise impact on surrounding residents.

We understand that the minor changes have been proposed to the link section and escape stair between the existing building and proposed hall extension. The revised ground floor plan is shown in Figure 1, with the link section clouded.




Figure 1 - Proposed ground floor plan showing revised link section

There are no significant changes to proposals for the hall extension, reception classroom or kindergarten. We therefore do not expect any significant change to proposed activity noise levels. The proposed change to the link section therefore would not result in increased noise impact to neighbouring properties.

---

### Memo Status

Rev	Date	Prepared by	Checked by
-	8 March 2024	Ian Rees MIOA	Andy Thompson MIOA

---

### Disclaimer

This memorandum was completed by Adrian James Acoustics Ltd. on the basis of a defined programme of work and terms and conditions agreed with the Client. The memorandum has been prepared with all reasonable skill, care, and diligence within the terms of the Contract with the Client and taking into account the project objectives, the agreed scope of works, prevailing site conditions and the degree of manpower and resources allocated to the project. Recommendations in this memorandum are for acoustic purposes only, and it is the responsibility of the Project Manager or Architect to ensure that all other requirements are met including (but not limited to) structure, fire, and Building Controls.

Adrian James Acoustics Ltd accepts no responsibility, following the issue of the memorandum, for any matters arising outside the agreed scope of the works.

Any surveys were conducted, and this memorandum has been prepared, for the private and confidential use of the client only and cannot be reproduced in whole or in part, or relied upon by any third party for any use whatsoever, without the express written authorisation of Adrian James Acoustics Ltd. If any third party whatsoever comes into possession of this memorandum, they rely on it at their own risk and Adrian James Acoustics Ltd. accepts no duty or responsibility (including in negligence) to any such third party.

Unless specifically assigned or transferred within the terms of the agreement, Adrian James Acoustics Ltd. retains all copyright and other intellectual property rights, on and over the memorandum and its contents.

© Adrian James Acoustics Ltd. 2024