

DO NOT SCALE. USE FIGURED DIMENSIONS ONLY.

60min FR Separation - NEW

Fire Strategy Legend 30min FR Separation - NEW

30min FR Separation - EXISTINGExisting wall to provide 30 minutes Fire
Resistance - survey & repair as required

60min FR Separation - EXISTING Existing wall to provide 60 minutes Fire Resistance - survey & repair as required FD30 Door - NEW

FD30s indicates smoke seals are required. FD60 Door - NEW FD30s indicates smoke seals are required.

FD30 Door - EXISTING
FD30s indicates smoke seals are required.

FD60 Door - EXISTING FD30s indicates smoke seals are required. Refer to schedule for remedial work required.

Room Occupancy
Exit capacities are based on the occupancies shown and these must not be exceeded. 900 x 1400mm Wheelchair Refuge

Door on hold opener

Directional escape signage shown on plan.
Final locations to be agreed with RBCA on site.
Fire escape signage will either be illuminated type as per MEP specification or as N15

Circulation - Escape Stair

Areas of Special Fire Hazard

Extent of Fire Compartment - boundary to be 60mins fire resisting ── 30/15 ceiling/ loft cavity barrier Specification: P10/432A

60/60 ceiling/ loft cavity barrier Specification: P10/432B

P03 Revised as clouded P02 Revised As Clouded For Tender

REV DESCRIPTION

12.04.24

Thomas's London Day Schools

Thomas's College - Red House

Red House - Fire Strategy Plan -Sheet 1

SCALE @ A1: 1:100

RAWING NUMBER 1714 IID C XX DR A-1600 P03