












Existing Drama Room
Section A-A


Legend

-  Existing timber rafter 150 x 50mm
-  Existing hip rafter 175 x 62mm
-  Existing gutter
-  Existing metal tanking (waterproofing)
-  Existing wall plate and timber packing
-  denotes location of replacement slates




Drama Room
Existing Roof Plan

-  2024 Repairs - Replaced rotted wallplate with brickwork infill
-  2024 Repairs - Cut out dry rot / spliced new timber rafters alongside
-  2024 Report Proposals - Replace rotted wallplate - Wallplate to be replaced per Tapco Report dated 4th September 2024
-  2024 Report Proposals - Rafters to be replaced per Tapco Report dated 4th September 2024



SCALE 1:50



FOR LISTED BUILDING CONSENT

P3	Listed building consent issue. proposed remedial works shown.	25.09.24	PJP	Client	DUFFY ASSOCIATES BUILDING · ENGINEERING · DESIGN 76 New King's Road · London · SW6 4LT T 0207 042 8290 · declanduffy@duffyassociates.co.uk
P2	Listed building consent issue. Location of replacement slates indicated.	01.07.24	PE	Hampton Court House School	
P1	Listed building consent issue.	26.06.24	PE	Drawing title	Scale 1:50 (A3)
				Drama Room. Existing Roof structure plan and section A-A.	Date JUN 2024
				Property	Drawing Number 2425.S01
				Hampton Court House School	Drawn By PE
					Figured dimensions only to be taken from this drawing. Any errors or omissions to be reported to the Architect/Engineer.
					Copyright retained by DUFFY ASSOCIATES LTD