12 Strathearn Avenue Twickenham TW2 6JU

Flood Risk Assessment-

Proposed single storey rear extension & part two storey part single storey side extension

Nov '24

Applicant to choose one or other of the flood mitigation measures below.	Applicant to provide the LPA with the supporting Information detailed below as part of their FRA	Applicant to tick one of the boxes below
Either; Floor levels within the proposed development will be set no lower than existing levels AND, Flood proofing of the proposed development has been incorporated where appropriate.	Details of any flood resilience and resistance techniques to be included in accordance with 'Preparing for floods' (ODPM 2003)	✓
Or; Floor levels within the extension will be set 300mm above the known or modelled 1% (1 in 100 chance each year) river flood level or 0.5% (1 in 200 chance each year) tidal & coastal flood level.	This must be demonstrated by a plan that shows finished floor levels relative to the known or modelled flood level. All levels should be stated in relation to Ordnance Datum	