



Daylighting Assessment for 94 Temple Sheen Road



ALLZA
ALLZA DESIGN & CREATIVE

Chiswick Business Park, Building 3
W4 5YA, London
T +447342843559
www.allza.org

Ground Floor




Furnes Loudge

11.7 m


Furnes Loudge

5.7 m

Non habitable room window
- Opaque glazed




1st Floor




Furnes Loudge


Furnes Loudge

Non habitable room window
- Opaque glazed





This image illustrates that the 25-degree line from the nearest window of the neighboring property clears both the existing boundary wall and the proposed extension, indicating that our proposed design will not obstruct daylight.



This image illustrates that the 25-degree line from the nearest window of the neighboring property clears both the existing boundary wall and the proposed extension, indicating that our proposed design will not obstruct daylight.



Existing boundary wall

This image, taken from the midpoint of the nearest window of the neighboring property, demonstrates that the proposed rear additions for 94 Temple Sheen are not visible from this window due to the existing boundary wall.



The set back design articulation around the existing boundary wall enables the proposed rear extension for 94 Temple Sheen to comply with the 25 degree rule.

Thank You

ALLZA Design & Creative